

ROOF REPPLEMENT  
505 HUDSON STEREET  
HARTFORD, CONNECTICUT  
PROJECT: BI - 2B - 304


<b>BID OPENING</b>	<b>1:00 P.M.</b>	<b>DECEMBER 10, 2013</b>
<b>ADDENDUM NUMBER #3</b>	<b>DATE OF ADDENDUM</b>	<b>DECEMBER 9, 2013</b>

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

The existing insulation is a tapered polyisocyanurate insulation system. The minimum approximate depth is 2 (two) inches, The average depth is approximately 4 (four) inches.

End of Addendum Number Three



---

Mellanee Walton  
Associate Fiscal Administrative Officer  
Department of Administrative Services