

ADDENDUM NO.: 02

DATE OF ADDENDUM: July 21, 2014

Roof Replacement CT Fire Academy
34 Perimeter Road, Windsor Locks, CT 06096
BI – N – 330

Original Bid Due Date / Time:	July 23, 2014	1:00 pm EDT
Revised Bid Due Date / Time:	July 30, 2014	1:00 pm EDT
Previous Addendums: No. 1 (July 16, 2014)		

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated March 5, 2014. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

The Bid Due Date has been extended from **Wednesday July 23, 2014 @ 1:00 PM to Wednesday, July 30, 2014 at 1:00 PM**

Item 2

In Section 07 52 00, Delete paragraph 1.10 A.

- Refer to Section 00 11 16 Invitation to Bid dated June 20, 2014 regarding DAS Contractor Prequalification Classification Name, i.e. Group A - General Building Construction.

Item 3

In Section 07 52 00, replace paragraphs 2.02 A and B with the following:

- 2.02 A: Roofing system shall be a three-ply modified bitumen cold applied system meeting the minimum requirements of ASTM D 6162 or 6163. The two base plies shall be smooth surfaced minimum Type 1, Grade S, and the cap sheet shall be a granular surfaced, minimum Type 1, Grade G sheet. Cap sheet color to be selected by the Owner. Acceptable manufacturer systems are listed below:
 - Siplast Paradiene 20/30
 - Tremco PowerPly
 - The Garland Company StressPly
- 2.02 B: Two-ply stripping and base flashing membrane shall consist of one ply of asphalt coated sheet (described in 2.02A) and one ply of the roof membrane manufacturers granular surfaced, SBS modified bitumen membrane. The color of the granular sheet shall match that of the field of roof sheet. Should the manufacturer have an approved liquid applied flashing system (color to match the granular sheet) or elastomeric flashing membrane which is compatible with the approved roof system, and part of their system warranty, these substitutions will be considered

ADDENDUM NO.: 02

DATE OF ADDENDUM: July 21, 2014

for this project at no additional cost to the Owner, and shop drawings will be required to show the representative changes.

- Membrane system shall be as specified and as required to obtain the specified 25-year warranty and to comply with specified FM Global wind uplift requirements.

Item 4

In Section 07 52 00, Delete paragraphs 2.02 D, 2.02 E, 2.02 F, 2.02 G, 2.02 H, and 2.02 I.

- Membrane adhesive shall be a Connecticut low-VOC compliant adhesive as required by the manufacturer to obtain the specified 25-year warranty and to comply with specified FM Global wind uplift requirements.

Item 5

In Section 07 52 00, delete paragraph 2.05. See item #3 2.02 B, above.

End of Addendum #2



Mellanee Walton, Associate Fiscal Administrative Officer
Department of Administrative Services
On Behalf of the Division of Construction Services