

ADDENDUM NO.: 2

DATE OF ADDENDUM: 19 November 2014

**Connecticut Fire Academy
Repair and Renovate Fire Escapes
34 Perimeter Road
Windsor Locks, CT
BI – N – 331**

Original Bid Due Date / Time:

November 25, 2014

1:00 PM

Previous Addendums: Addendum #1 dated November 17, 2014

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 29 July 2014. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.


Item 1

In response to RFIs regarding powder coating and new stair fabrication, please note the following:

- a. New stairs can be fabricated in sections to simplify powder coating process, delivery to site and installation.
- b. New stairs should be fabricated in the maximum number of sections – as practical for fabrication and delivery.
- c. New stair sections and components may be mechanically fastened in the field if preferred. Contractor to make accommodations for proposed method of installation and field fabrication. All fasteners and related items to be field painted to match new stair.
- d. Powder coated components that require field welding should be ground smooth as required for field welding and field painted to match new stair.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Architect/Engineer (Steven Iovanna, BL Companies, fax: 203-630-2615) with copies sent to the CT DCS Project Manager (Steven Udeh, fax: 860-713-7261)

End of Addendum 2



Mellanee Walton, Associate Fiscal Administrative Officer
Department of Administrative Services
On Behalf of the Division of Construction Services