

ADDENDUM NO.: 3

DATE OF ADDENDUM: March 31, 2015

**ELEVATOR UPGRADE  
DEPARTMENT OF CORRECTIONS  
24 Wolcott Hill Road  
Wethersfield, CT  
BI- 2B-284**

Original Bid Due Date / Time:

April 8, 2015

1:00 PM

Previous Addendums: Addendum #2 dated March 30, 2015, Addendum #1 dated February 6, 2015

**TO: Prospective Bid Proposers:**

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated Sept 19, 2014. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

**Item 1**

Question: Drawing ME4: Calls for Greenheck S1-436 this model is not complete. Please verify model of fan you would like us to use or use as or equal.

Answer: Question refers to Drawing ME 404 Detail 2. Provide fan with the listed options noted in Detail 2. Delete reference to model #. Provide fan with the following performance:

- 16" direct drive propeller exhaust fan
- 1600 cfm @ 0.125" w.g.
- 860 rpm
- 1/8 hp

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Engineer (Fuss & O'Neil attn.: Allen Pigeon and Fax Number 860.645.0717) with copies sent to the CT DCS Project Manager (Ward Ponticelli, RA and Fax Number 860.713.7261).

End of Addendum 3

  
Mellanee Walton, Associate Fiscal Administrative Officer  
Department of Administrative Services  
On Behalf of the Division of Construction Services