

ADDENDUM NO.: 3

DATE OF ADDENDUM: November 3, 2015

**Roof Replacements Danbury/Torrington  
400 Main Street, Danbury & 195 Alvord Park Road, Torrington, CT  
BI – NN - 671**

---

Original Bid Due Date / Time: November 4, 2015 1:00 pm

---

Revised Bid Due Date / Time: November 18, 2015 1:00 pm

---

Previous Addendums: Addendum #2, dated October 1, 2015, Addendum #1 dated September 23, 2015

---

**TO: Prospective Bid Proposers:**

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated April 17, 2015. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

**Item 1**

The bid opening will be changed from November 4, 2015 at 1:00 pm to November 18, 2015 at 1:00 pm.

**Item 2**

Specification Section 075323.2.1 Products, change the 60-mil white EPDM called for to 90-mil white EPDM to maintain a 30-year warranty specified.

**Item 3**

Specification section 075323.2.4.F delete and replace with Substrate: ASTM C 1177/C 1177M, glass-mat, water-resistant gypsum substrate, 1/2 inch thick.


**Item 4**

**Add:** Specification section 075323.2.4.G Cover Board: As recommended by manufacturer, if required for system warranty.

**Item 5**

**Add:** Specification section 075323.2.4.H Vapor Barrier/retarder: Based on "Cav Grip" by Carlisle-Syntec over existing metal deck and below the new 1/2" substrate; and on existing concrete deck where noted in the Roof Types on Drawing A2-401.

End of Addendum 3



---

Mellanee Walton, Associate Fiscal Administrative Officer  
Department of Administrative Services  
On Behalf of the Division of Construction Services