

ADDENDUM NO.: 4

DATE OF ADDENDUM: May 19, 2016

**Renovations to Litchfield Residence Hall  
Western Connecticut State University  
183 White Street  
Danbury CT  
CF – RD – 275**

Original Bid Due Date / Time:

May 25, 2016

1:00 PM

Previous Addendums: Addendum #3 dated 5/18/2016, Addendum #2 dated 4/25/2016, Addendum #1 dated 4/25/2016

**TO: Prospective Bid Proposers:**

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 2/17/2016. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

**Item 1**

**Wardrobe Scope:**

The wardrobe work scope shall be included as follows: The existing wardrobes indicated by notes 4, 4A & 4B on drawings A-101, 102 & 103 shall be removed from the dorm rooms by the abatement contractor and stored in the Lounges on that floor to allow for abatement work to be completed in the dorm rooms. The GC shall reinstall wardrobes in dorm rooms and complete restoration to the wardrobes as detailed on drawing A-602 and ED-101, 102 & 103. The GC has the option of performing restoration while the wardrobes are in the Lounges or after they are reinstalled in the dorm rooms. The following Items 2 & 3 restore the work previously deleted in Addenda #3. - Item 14.

**Item 2**

Drawing A-602 Detail 11, 12, 13 & 14, General Note for existing millwork and ED-101, 102 & 103 note 14.

**ADD BACK:** Drawing A-602 Detail 11, 12, 13 & 14, General Note for existing millwork and ED-101, 102 & 103 note 14.

**DELETE:** SKA-4 and described work issued in Addenda #3 detailing repair work at removed wardrobe millwork locations.

**Item 3**

Drawing AD-101, 102 & 103 note 9.1.


**DELETE:** Note 9.1

**Item 4**

Section 08 13 16 - 2.03 A

**CHANGE:** 18ga. for interior doors to 16ga. for interior doors

End of Addendum No. 4



Mellanee Walton, Associate Fiscal Administrative Officer  
Department of Administrative Services  
On Behalf of the Division of Construction Services