

ADDENDUM NO.: #2

DATE OF ADDENDUM: February 15, 2017

**OCME COOLER EXPANSION
11 SHUTTLE ROAD
FARMINTON, CT
BI-2B-426**

Bid Due Date / Time:

March 1, 2017

1:00 pm

Previous Addendum's: Addendum #1 dated 2/8/2017

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 1/20/2017. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Question: We have a question regarding the insulation on the refrigeration piping. The spec is written for the air conditioning piping, using 1" fiberglass insulation with a metal jacketing. Normally we use Armstrong Armaflex on refrigeration piping. Will this be acceptable? Do they need metal jacketing over the Armaflex? Please advise.

Answer: Yes, Armstrong Armaflex pipe insulation is an acceptable equivalent to the specified fiberglass in Section 23-07-19. Yes, protective metal jacket is required.

Item 2

The deadline for RFI's shall be Friday February 17, at 5:00 PM.

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Engineer (Alan Aldag, BVH Integrated Services, PC, fax # 860-242-0236) with copies sent to the DAS Project Manager (Ashour Gevargisnia, CT DCS Right Fax # 860-622-2947)

End of Addendum #2



Mellanee Walton, Associate Fiscal Administrative Officer
State of Connecticut
Department of Administrative Services, Construction Services
Process Management and Procurement Unit
450 Columbus Boulevard, Suite 1302
Hartford, CT 06103