

ADDENDUM NO.: #3

DATE OF ADDENDUM: February 23, 2017

**OCME COOLER EXPANSION
11 SHUTTLE ROAD
FARMINTON, CT
BI-2B-426**

Bid Due Date / Time:

March 1, 2017

1:00 pm

Previous Addendum's: Addendum #2 dated 2/15/2017, Addendum #1 dated 2/8/2017

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 1/20/2017. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

In Specification Section 114121 – WALK-IN COOLER, revise the following as noted:

1. 2.2 WALK-IN COOLER CONSTRUCTION, E. Wall and Ceiling Panel Construction, 6. Door Panel and Door: item c. – Replace "aluminum diamond plate" with "stainless steel."
2. 2.2 WALK-IN COOLER CONSTRUCTION, E. Wall and Ceiling Panel Construction, 6. Door Panel and Door: item d. – Delete this item. No closer is required.
3. 2.2 WALK-IN COOLER CONSTRUCTION, G. Rub rail wall protectors: – Replace "Manufacturer's standard" with "Stainless steel". Add "Coordinate mounting height with Owner's conveyor gurneys."
4. 2.3 CONDENSING UNITS, H. Air Cooled Condensing Units: item 2. – Replace "split capacitor motors" with "EC motors."
5. 2.4 UNIT EVAPORATOR COOLER, C. Motors: – Replace "split capacitor" with "EC".

All questions must be in writing (not phone or e-mail) and must be forwarded to the consulting Engineer (Alan Aldag, BVH Integrated Services, PC, fax # 860-242-0236) with copies sent to the DAS Project Manager (Ashour Gevargisnia, CT DCS fax # 860-622-2947)

End of Addendum #3



Mellanee Walton, Associate Fiscal Administrative Officer
State of Connecticut
Department of Administrative Services, Construction Services
Process Management and Procurement Unit
450 Columbus Boulevard, Suite 1302
Hartford, CT 06103