



Addendum No.: 2

Date of Addendum: December 8, 2017

CT DAS • Construction Services • Process Management and Procurement Unit

State Records Center & Library for the
Blind and Physically Handicap Roof Replacements
198 West Street
Rocky Hill, CT 06067
BI – SS – 116

Original Bid Due Date / Time: December 13, 2017 1:00 PM

Revised Bid Due Date / Time: NA NA

Previous Addenda: Addendum #1 dated 11/29/2017

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated July 21, 2015. Prospective Bid Proposers **shall** acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form.

Failure to acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form **shall** subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1:

QUESTION: Is Air Testing and Balancing required for this Project?

ANSWER: No.

Item 2:

QUESTION: What is the Scope of brick repointing?

ANSWER: The existing masonry chimney at the State Records Center.

Item 3:

QUESTION: Please confirm that the work can occur uninterrupted during normal business hours (7:00 AM – 3:30 PM) while the buildings are occupied.

ANSWER: Yes, work can be done uninterrupted during normal business hours (7:00 AM – 3:30 PM) while building is occupied.

Item 4:

QUESTION: If the work is occurring during normal business hours while the building is occupied, will overhead protection at egress points be required?

ANSWER: Yes.

Item 5:

QUESTION: Does existing metal deck conform to FM Global standards? If not, are we required to secure the deck per FM Global requirements?

ANSWER: Unless disturbed, the deck will not require additional fastening.

All questions must be in writing (not phone) and must be forwarded to the consulting Architect/Engineer, Ken Linsley (E-mail: klinsley@silverpetrucelli.com) with copies sent to the DAS Project Manager, Steven Udeh (E-mail: steven.udeh@ct.gov).



Addendum No.: 2

Date of Addendum: December 8, 2017

End of Addendum Number 2

Mellanee Walton

Mellanee Walton, Associate Fiscal Administrative Officer
State of Connecticut
Department of Administrative Services
Construction Services
Office of Legal Affairs, Policy & Procurement