



Addendum No.: 4

Date Of Addendum: August 13, 2018

CT DAS | Construction Services | Office of Legal Affairs, Policy, and Procurement

Renovations to Physical Plant
Naugatuck Valley Community College
750 Chase Parkway
Waterbury, CT
BI-CTC-500

Bid Due Date / Time: August 22, 2018 1:00 PM

Previous Addendums: Addendum #3 dated 8/9/2018, Addendum #2 dated 8/8/2018, Addendum #1 dated 7/25/2018

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated March 23, 2018. Prospective Bid Proposers **shall** acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form.

Failure to acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form shall subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1:

QUESTION: Are photographs available of the existing Federal Pacific secondary unit substation that is to be modified under the contract?

RESPONSE: The dimensions of the existing gear is 37 inches deep by 92 inches high. See three photos below.





Addendum No.: 4

Date Of Addendum: August 13, 2018





Addendum No.: 4

Date Of Addendum: August 13, 2018



All questions must be **written** (not verbal or by phone) and must be forwarded to the consulting Engineer (Jerry Alverson, Email: JerryA@bvhis.com) with copies sent to the DAS/CS Project Manager (Joel Baranowski, Email: Joel.Baranowski@ct.gov) and Construction Administrator (Steve Buccheri, Email: SteveBuccheri@newfieldconstruction.com)

End of Addendum Number 4

Mellanee Walton, Associate Fiscal Administrative Officer
State of Connecticut
Department of Administrative Services, Construction Services
Office of Legal Affairs, Policy, and Procurement
450 Columbus Boulevard, Suite 1302
Hartford, CT 06103