



Addendum No.: 6

Date Of Addendum: January 8, 2021

CT DAS | Construction Services | Office of Legal Affairs, Policy, and Procurement

Northern CI Alarm Replacement
287 Bilton Road
Somers, CT
BI – JA – 491

Original Bid Due Date / Time:

January 20, 2021

1:00 PM

Previous Addendums: Addendum #5 dated 1/7/2021, Addendum #4 dated 1/5/2021, Addendum #3 dated 12/28/2020, Addendum #2 dated 12/15/2020, Addendum #1 dated 12/4/2020

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 9/30/2020. Prospective Bid Proposers **shall** acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form.

Failure to acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form shall subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1: RFI Responses

Below is the response to RFI questions received from Convergent on 1/6/2021:

1. **Question:** With respect to spec section [1.7.4.3](#) A, B and C, since most speaker strobes are being installed in existing locations, the design layout is in place based on scope. How do we address this spec criteria when all locations are shown? Does the current system meet this criteria?

Answer: MODIFY: Specification Section 28 31 11, 1.7.4.3. to read as follows:

1.7.4.3. Audio (Speaker) Notification Appliance Circuits - Interior

- A. The system shall be designed for interior building audibility level of 15 dBA-fast over ambient condition.
- B. Provide dB loss calculations for all audio (speaker) notification appliance circuits. Circuits shall be designed for no more than 0.5 db loss based on lump-sum load method.

All questions must be **emailed** (not **verbal** or by **phone**) to the consulting Architect/Engineer (Michael Hebert, Email: mhebert@a-zcorp.com) with copies sent to the DAS/CS Project Manager (Ashour Gevargisnia, Email: Ashour.Gevargisnia@ct.gov) and Construction Manager (NA, Email: NA)

End of Addendum 6

Mellanee Walton

Mellanee Walton, Associate Fiscal Administrative Officer
State of Connecticut
Department of Administrative Services, Construction Services
Office of Legal Affairs, Policy, and Procurement
450 Columbus Boulevard, Suite 1302
Hartford, CT 06103