

**Exhibit F - Task and Frequency Schedule
Data Room - Hartford**

	SERVICE DESCRIPTION	FREQUENCY	
		Semi - Annual	ANNUAL
1	Carefully vacuum cable trays, tops of power panels, UPS, 10 cabinets and 3 racks, wiping down any remaining areas with a damp cloth.	Semi-annual	Annual
2	Thoroughly vacuum floor area and under cabinets.	Semi-annual	Annual
3	Scrub electro-static discharge ("ESD") floor area using a ESD floor finish.	Semi-annual	
4	Wash ESD floor surface after vacuuming		Annual
5	Any cabinet with more than two feet (high) clearance empty cabinet space at the bottom will be opened and vacuumed and wiped with damp cloth.	Semi-annual	Annual
6	Air quality test (as described in Exhibit A, section 2 "Services" - 7)		Annual