

BID ADDENDUM
SP-18 Rev. 11/17/16
Prev. Rev. 3/13/14

Eva Orlinski
Contract Analyst
860-713-5083
Telephone Number

STATE OF CONNECTICUT
DEPARTMENT OF ADMINISTRATIVE SERVICES
PROCUREMENT DIVISION
450 Columbus Boulevard, Hartford, CT 06103

BID NO.: 18PSX0329
Bid Due Date: 11 February 2019
Date Addendum Issued: 6 February 2019

PLEASE NOTE:

This document has been marked as "Returnable". Electronic submittal of this document indicates that your company has read and accepted any modifications to the bid that are contained in this Addendum.

BID ADDENDUM #2

DESCRIPTION:

HVAC SERVICES, INSPECTION AND PREVENTATIVE MAINTENANCE SERVICES AT THE ROWLAND STATE GOVERNMENT CENTER, 55 AND 395 WEST MAIN STREET, WATERBURY FOR DAS AND DCF

FOR:

Department of Administrative Services and Department of Children and Families

BIDDERS NOTE:

This Addendum is to clarify that at the Rowland State Government Center, 55 West Main Street location there are 76 VAV's with filters. The filters on the VAV's need to be changed annually. The remaining VAV's have heating coils with no filters.