



Eastern Connecticut State University
Willimantic, Connecticut 06226-2295

HTHW Manhole #1S Replacement

Project: **ECSU 2018-11**

ADDENDUM NUMBER 2

Date of Addendum: January 30, 2019

Bids Due: **2:00 P.M. on February 6th, 2019** in the Purchasing Department, Third Floor, Room 344 of the Gelsi-Young Hall (Administration Building along High Street)

The following clarifications are applicable to Construction Drawings and Project Manual for the project referenced above:

Addendum Items:

- ITEM 1: Re: Specifications Division Section 230523.13 Butterfly Valves for HVAC Piping, paragraph 2.1 E.1.
Replace the paragraph E.1 beginning with wording "Gear Actuator: For valves..." with the following wording:
"Gear Actuator: For valves 3" or larger. Carbon steel housing with stainless steel shaft. High temperature gear operator suitable to withstand temperature of 390 deg F."

END OF ADDENDUM #2