

BID ADDENDUM

Name Lisa LeFrancois

Title Fiscal Administrative
Officer

Telephone Number 860-692-
7725

STATE OF CONNECTICUT

DEPARTMENT OF CORRECTION

FISCAL SERVICES

24 Wolcott Hill Road – 2nd FL

WETHERSFIELD, CT 06109

BID NO:

19DOC0510AA

Bid Due Date:

February 14, 2019

BID ADDENDUM #2:

Questions and Answers:

1. All work WILL NOT be able to be completed in 30 days. It is estimated that this will take a minimum of 60 days. Is this acceptable? **60 days is the maximum amount of days.**
2. Sam Sacks, the Dur-A-Flex representative (Phone: 401-369-6564), recommends the floors to be *Hybri-Flex AQ* – colored quartz. Is this acceptable? **Hybri-Flex AQ is acceptable but the color will be determined by DOC.**
3. How many 110v electrical circuits will be provided at Radgowski? **4 20 amp circuits**
4. How many amps will each 110v electrical circuit at Radgowski be? **4 20 amp circuits**
5. How many amps will each 110v electrical circuit at Corrigan be? **2 20 amp circuits**

BIDDERS NOTE:

This Addendum must be *Signed & Returned* with your Bid.

Authorized Signature of Bidder

Company Name

APPROVED Lisa M. LeFrancois

Fiscal Administrative Officer

Date issued: February 8, 2019