



Addendum No.: 5

Date Of Addendum: 3/5/19

CT DAS ● Construction Services ● Office of Legal Affairs, Policy, and Procurement

York Correctional Institution Central Plant and Piping Distribution

201 West Main Street, Niantic, CT

BI – JA – 465

Original Bid Due Date / Time:

3/07/19

2:00 PM EST

Previous Addendums: Addenda 1, 2, 3, & 4

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated 12/21/18. Prospective Bid Proposers **shall** acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form.

Failure to acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form shall subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1:

See attached Fan Coil Unit (FCU) schedule for Buildings 5, 7, 8, 9A, 9C, 10, 11, and 12 per the pre-bid response A121.

Item 2:

Section 23 09 23 Building Management System

REPLACE the points list with the attached which incorporates updates released with the pre-bid questions/responses.

Item 3:

Section 23 09 99 Buildings – Sequence of Operation

REPLACE the entire section with the attached to address several pre-bid questions/responses issued with Addendum 4.

SUMMARY OF CHANGES

UPDATED Sequence of Operation for Bldgs 9B, 9C, and 9D, 10A, 11, 12, and 13.

REMOVED Unit heaters and convectors.

ADDED Exhaust fans including EF4-4, 4-5, 4-6, 4-7, & 4-8 (Building 4)

Item 15:

Section 00 01 10 Table of Contents (for all three (3) Project Manual volumes)

UPDATE the page counts in the Addendum 4 Table of Contents for the following Specification section items:

"23 09 23 Building Management System" from "65" to "66"

"23 09 99 Buildings – Sequence of Operation" from "19" to "24"

End of Addendum 5

FAN COIL UNIT SCHEDULES

| BLDG | TAG | COOLING COIL | | | | | HEATING COIL | | | |
|------|---------|--------------|-------|-------|-----|-----|--------------|-------|-----|-----|
| | | MBH | | WATER | | | MBH | WATER | | |
| | | SENS | TOTAL | GPM | EWT | LWT | | GPM | EWT | LWT |
| 5 | FCU5-1 | 8.9 | 12.6 | 2.2 | 45 | 57 | 19.1 | 1.5 | 180 | 160 |
| | FCU5-2 | 7.8 | 14 | 2.3 | 45 | 57 | 13 | 1 | 180 | 160 |
| | FCU5-3 | 22 | 34 | 5.3 | 45 | 57 | 45 | 3 | 180 | 160 |
| | FCU5-4 | 16 | 27 | 3.5 | 45 | 57 | 41 | 3.5 | 180 | 160 |
| 7 | FCU7-1 | - | 12 | 1.27 | - | - | - | - | - | - |
| | FCU7-2 | - | 9 | 1 | - | - | - | - | - | - |
| 8 | FCU8-1 | 24 | 26 | 2 | 45 | 57 | 11 | 2 | 180 | 160 |
| | FCU8-2 | 10 | 13 | 2 | 45 | 57 | 5.5 | 2 | 180 | 160 |
| 9A | FCU9A-1 | - | - | - | - | - | 9.4 | 1 | 180 | 160 |
| | FCU9A-2 | - | - | - | - | - | 9.4 | 1 | 180 | 160 |
| 9C | FCU9C-1 | 8.9 | 13.7 | 1.9 | 45 | 57 | 22 | 2 | 180 | 160 |
| | FCU9C-2 | 8.9 | 13.7 | 1.9 | 45 | 57 | 22 | 2 | 180 | 160 |
| | FCU9C-3 | 5.1 | 7.9 | 1.4 | 45 | 57 | 21 | 1.5 | 180 | 160 |
| | FCU9C-4 | 7 | 10.8 | 1.9 | 45 | 57 | 21 | 2 | 180 | 160 |
| | FC9UC-5 | 7 | 10.8 | 1.9 | 45 | 57 | 21 | 2 | 180 | 160 |
| 10 | FCU10-1 | 31.4 | 34.3 | 11.8 | 45 | 57 | 77.6 | 2 | 180 | 160 |
| 11 | FC11-1 | 8.9 | 12.6 | 2.2 | 45 | 57 | 19.1 | 1.5 | 180 | 160 |
| | FC11-2 | 7.8 | 14 | 2.3 | 45 | 57 | 13 | 1 | 180 | 160 |
| | FC11-3 | 22 | 34 | 5.3 | 45 | 57 | 45 | 3 | 180 | 160 |
| | FC11-4 | 16 | 27 | 3.5 | 45 | 57 | 41 | 3.5 | 180 | 160 |
| 12 | FC12-1 | 16 | 22 | 4 | 45 | 57 | 28 | 1 | 180 | 160 |
| | FC12-2 | 11 | 15.5 | 3 | 45 | 57 | 28 | 1 | 180 | 160 |

| | A | B | C | D | E | F | G | H | I | J |
|----|--|--|--|--------|----|----|----|-----------------------|---|---------------------|
| 1 | YORK CORRECTIONAL FACILITY - BMS POINTS SCHEDULE | | | | | | | | | |
| 2 | THE FOLLOWING POINT SCHEDULE IS FOR REFERENCE ONLY. THIS CONTRACTOR IS RESPONSIBLE TO COORDINATE ALL WORK SPECIFIED WITHIN THE CONTRACT DOCUMENTS, SEQUENCES OF OPERATIONS AND WORK ASSOCIATED WITH OTHER TRADES. ANY DISCREPANCY BETWEEN CONTRACT DOCUMENTS SHALL RESOLVE WITH THE MORE COSTLY, COMPLEX OR STRINGENT TAKING PRECEDENT. NOTE THAT SYSTEMS ARE LISTED AS TYPICAL. | | | | | | | | | |
| 4 | | | | | | | | | | |
| 5 | | | | POINTS | | | | | | |
| 6 | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 7 | <u>CP-0-1.2, 3, 4, 5 (TYP OF 5)</u> | AHU0-1,2, 3, 4, 5(TYP OF 5) | BLDG. 1 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. CONTRACTOR IS TO COORDINATE AND VERIFY CONDUIT RUNS PRIOR TO INSTALLATION. | CONTROLLER OFFLINE |
| 8 | | OUTDOOR AIR DAMPER | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 9 | | MIXED AIR DAMPER | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 10 | | FILTER STATUS | AHU0-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 11 | | MIXED AIR TEMPERATURE SENSOR | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 12 | | SPACE HUMIDITY SENSOR | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | | F/I NEW SENSOR | % RH / HI RH |
| 13 | | SUPPLY FAN START / STOP | AHU0-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON/OFF |
| 14 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU0-1,2, 3, 4, 5(TYP.) | | 5 | | | DO | F/I NEW SWITCH | STATUS - ON/OFF |
| 15 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU0-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 16 | | EXHAUST FAN - START / STOP - CT | AHU0-1,2, 3, 4, 5(TYP.) | | 5 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 17 | | EXHAUST FAN DAMPER ACTUATOR | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 18 | | HOT DECK VALVE | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONTRACTOR | % OPEN |
| 19 | | COLD DECK VALVE | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONTRACTOR | % OPEN |
| 20 | | HOT DECK SUPPLY TEMP | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 21 | | COLD DECK SUPPLY TEMP | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 22 | | RETURN HUMIDITY | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | % HUM / HI HUM |
| 23 | | RETURN TEMP | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 24 | | ZONE 1 RETURN TEMP | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 25 | | ZONE 2 RETURN TEMP | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 26 | | ZONE 3 RETURN TEMP | AHU0-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 27 | | ZONE 1 DAMPER | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 28 | | ZONE 2 DAMPER | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 29 | | ZONE 3 DAMPER | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 30 | EFO-6 | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU0-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 31 | EFO-6 | EXHAUST FAN - START / STOP - CT | AHU0-1 | | 1 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | STATUS |
| 32 | EFO-6 | EXHAUST FAN DAMPER ACTUATOR | AHU0-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 33 | | AHU1-1 SMOKE DETECTOR | AHU0-1,2, 3, 4, 5(TYP.) | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 34 | EFO-7 | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU1-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 35 | EFO-7 | EXHAUST FAN - START / STOP - CT | AHU0-1,2, 3, 4, 5(TYP.) | | 1 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 36 | EFO-7 | EXHAUST FAN DAMPER ACTUATOR | AHU0-1,2, 3, 4, 5(TYP.) | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 37 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 38 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 39 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 40 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 41 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 42 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |

| 5 | A | B | C | D | E | F | G | H | I | J |
|----|--|---|--|----|----|----|----|-----------------------|---|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 43 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE | DEG. F / BTU |
| 44 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 45 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 46 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 47 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 48 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 49 | CP-HT-0 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 50 | | | | | | | | | | |
| 51 | CP-1-1,2, 3, 4, 5 (TYP OF 5) | AHU1-1,2, 3, 4, 5(TYP OF 5) | BLDG. 1 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. REFER TO FLOOR PLANS FOR SPECIFIC LOCATION OF AHU CONTROL PANELS. | CONTROLLER OFFLINE |
| 52 | | OUTDOOR AIR DAMPER | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 53 | | MIXED AIR DAMPER | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 54 | | FILTER STATUS | AHU1-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 55 | | MIXED AIR TEMPERATURE SENSOR | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 56 | | SPACE HUMIDITY SENSOR | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | | F/I NEW SENSOR | % RH / HI RH |
| 57 | | SUPPLY FAN START / STOP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | ON/OFF |
| 58 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU1-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 59 | FAI1-1,2,3,4,5 | FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU0-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 60 | FAI1-1,2,3,4,5 | FAN - START / STOP - CT | AHU0-1,2, 3, 4, 5(TYP.) | | 5 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 61 | FAI1-1,2,3,4,5 | FAN DAMPER ACTUATOR | AHU0-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 62 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU1-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 63 | | EXHAUST FAN - START / STOP - CT | AHU1-1,2, 3, 4, 5(TYP.) | | 5 | | | DI | F/I CT - HAWKEYE | CONTROL |
| 64 | | EXHAUST FAN DAMPER ACTUATOR | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 65 | | HOT DECK VALVE | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 66 | | COLD DECK VALVE | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 67 | | HOT DECK SUPPLY TEMP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 68 | | COLD DECK SUPPLY TEMP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 69 | | RETURN HUMIDITY | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | % HUM / HI HUM |
| 70 | | RETURN TEMP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 71 | | ZONE 1 RETURN TEMP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 72 | | ZONE 2 RETURN TEMP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 73 | | ZONE 3 RETURN TEMP | AHU1-1,2, 3, 4, 5(TYP.) | | | 5 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 74 | | ZONE 1 DAMPER ACTUATOR | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 75 | | ZONE 2 DAMPER ACTUATOR | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 76 | | ZONE 3 DAMPER ACTUATOR | AHU1-1,2, 3, 4, 5(TYP.) | | | | 5 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 77 | | AHU1 THRU 5 SMOKE DETECTOR | AHU1-1,2, 3, 4, 5(TYP.) | 5 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 78 | EF1-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 8) | AHU1-1 ---- EF-10A (LOC.ATED COLUMN. 1-0.5) AHU1-2 ---- EF1-9 (LOCATED NEAR AHU-2) | 8 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|--|---|---|----|----|----|----|----------------------|--|---------------------|
| | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL/ POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 79 | EF1-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - START / STOP - CT (TYP. 8) | AHU1-3 ---- EF1-10C (LOCATED AT COLUMN 9.5a AHU1-4 ---- EF1-10D (LOCATED AT COLUMN 13-0,5) | | 8 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 80 | EF1-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN DAMPER ACTUATOR (TYP. 8) | AHU1-5 ---- EF1-10B (LOCATED T COLUMN 4.5A EF1-6 TOILETS A&B (LOCATED MECH MEZZ - COLUMN 3.5-E - NEAR AHU1-1 EF1-6A TOILETS C&D (LOCATED MECH MEZZ - COLUMN 10.5-E - NEAR AHU1-4 EF1-7 TOILETS | | | | 8 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 81 | AHU1-2 | SPACE TEMPERATURE SENSOR LOCATIONS | ZONE 1 - RM 1-101 ZONE 2 - RM 1-109 ZONE 3 - RM 1-113 ZONE 4 - RM 1-112 ZONE 5 - RM 1-115 | | | 1 | | AI | F/I ROOM STAT | DEG. F / HI TEMP |
| 82 | MAIN BUILDING MER CHILLED WATER SERVICE (TYPICAL FOR ALL BUILDINGS) | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 83 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 84 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 85 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 86 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 87 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 88 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE (TYPICAL FOR ALL BUILDINGS) | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 89 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 90 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 91 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 92 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 93 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 94 | EF2-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 8) | AHU2-1 ---- EF-10A (LOC.ATED COLUMN. 1-0.5) AHU2-2 ---- EF1-9 (LOCATED NEAR AHU) | 8 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 95 | EF2-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - START / STOP - CT (TYP. 8) | AHU2-3 ---- EF1-10C (LOCATED AT COLUMN 8.5a AHU2-4 ---- EF1-10D (LOCATED AT COLUMN 13-0,5) | | 8 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 96 | EF2-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN DAMPER ACTUATOR (TYP. 8) | AHU2-5 ---- EF1-10B (LOCATED T COLUMN 4.5A | | | | 8 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 97 | CP-HT-1 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 98 | | | | | | | | | | |
| 99 | <u>CP-2-1,2, 3, 4, 5 (TYP OF 5.)</u> | AHU2-1,2, 3, 4, 5(TYP OF 5) | BLDG. 2 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 100 | | OUTDOOR AIR DAMPER | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 101 | | MIXED AIR DAMPER | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 102 | | FILTER STATUS | AHU2-1,3,4, 5 (TYP.) | 4 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 103 | | MIXED AIR TEMPERATURE SENSOR | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|--|--------|----|----|----|-----------------------|--|---------------------|
| | | | | DI | DO | AI | AO | | | |
| 6 | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | | | | | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 104 | | SPACE HUMIDITY SENSOR | AHU2-1,3, 4, 5(TYP.) | | | 4 | | DO | F/I CT - HAWKEYE | % RH / HI RH |
| 105 | | SUPPLY FAN START/STOP | AHU2-1,3,4, 5 (TYP.) | | 4 | | | DI | F/I NEW SWITCH | ON/OFF |
| 106 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU2-1,3,4, 5 (TYP.) | 4 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 107 | | EXHAUST FAN - START / STOP - CT | AHU2-1,3,4, 5 (TYP.) | | 4 | | | DI | F/I CT - HAWKEYE | |
| 108 | | EXHAUST FAN DAMPER ACTUATOR | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 109 | | HOT DECK VALVE | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 110 | | COLD DECK VALVE | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 111 | | HOT DECK SUPPLY TEMP | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 112 | | COLD DECK SUPPLY TEMP | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 113 | | RETURN HUMIDITY | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | % HUM / HI HUM |
| 114 | | RETURN TEMP | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 115 | | ZONE 1 RETURN TEMP | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 116 | | ZONE 2 RETURN TEMP | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 117 | | ZONE 3 RETURN TEMP | AHU2-1,3,4, 5 (TYP.) | | | 4 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 118 | | ZONE 1 DAMPER | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 119 | | ZONE 2 DAMPER | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 120 | | ZONE 3 DAMPER | AHU2-1,3,4, 5 (TYP.) | | | | 4 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 121 | EF2-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 8) | AHU2-1 ---- EF2-10A (LOC.ATED COLUMN. 1-0.5) AHU2-2 ---- EF2-9 (LOCATED NEAR AHU) | 8 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 122 | EF2-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - START / STOP - CT (TYP. 8) | AHU2-3 ---- EF2-10C (LOCATED AT COLUMN 8.5a) AHU2-4 ---- EF2-10D (LOCATED AT COLUMN 13-0,5) | | 8 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 123 | EF2-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN DAMPER ACTUATOR (TYP. 8) | AHU2-5 ---- EF2-10B (LOCATED T COLUMN 4.5A) EF2-6 TOILETS A&B (LOCATED MECH MEZZ - COLUMN 3.5-E - NEAR AHU1-1) EF2-6A TOILETS C&D (LOCATED MECH MEZZ - COLUMN 10.5-E - NEAR AHU1-4) EF2-7 TOILETS | | | | 8 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 124 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 125 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 126 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 127 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 128 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 129 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 130 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 131 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 132 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 133 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 134 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 135 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 136 | CP-HT-2 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 137 | | | | | | | | | | |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|-------------------------------------|---|--|--------|----|----|---|-----------------------|---|--|
| | 6 | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | POINTS | | | | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| DI | | | | DO | AI | AO | | | | |
| 138 | CP-3-1,2, 3, 4, 5, 6 (TYP OF 6.) | AHU3-1,2, 3, 4, 5, 6 (TYP OF 6) | BLDG. 3 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 139 | | OUTDOOR AIR DAMPER | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 140 | | MIXED AIR DAMPER | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 141 | | FILTER STATUS | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | 6 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 142 | | MIXED AIR TEMPERATURE SENSOR | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 143 | | SUPPLY FAN START/STOP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | 6 | | | DO | F/I CT - HAWKEYE | ON/OFF |
| 144 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | 6 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 145 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | 6 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 146 | | EXHAUST FAN - START / STOP - CT | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | 6 | | | DI | F/I CT - HAWKEYE | ON/OFF |
| 147 | | EXHAUST FAN DAMPER ACTUATOR | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 148 | | HOT DECK VALVE | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 149 | | COLD DECK VALVE | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 150 | | HOT DECK SUPPLY TEMP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 151 | | COLD DECK SUPPLY TEMP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 152 | | RETURN HUMIDITY | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | % HUM / HI HUM |
| 153 | | RETURN TEMP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 154 | | ZONE 1 RETURN TEMP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 155 | | ZONE 2 RETURN TEMP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 156 | | ZONE 3 RETURN TEMP | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | 6 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 157 | | ZONE 4 RETURN TEMP | AHU3-4,6 (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 158 | | ZONE 5 RETURN TEMP | AHU3-5 | | | 1 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 159 | | ZONE 1 DAMPER | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 160 | | ZONE 2 DAMPER | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 161 | | ZONE 3 DAMPER | AHU3-1, 2, 3, 4, 5, 6 (TYP.) | | | | 6 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 162 | | ZONE 4 DAMPER | AHU3-4,6 (TYP.) | | | | 3 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 163 | | ZONE 5 DAMPER | AHU3-5 | | | | 1 | AO | F/I DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 164 | EF3-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 8) | AHU3-1 ---- EF3-10A (LOC.ATED COLUMN. 1-E5) AHU3-2 ---- EF3-10A (LOCATED COLUMN 4.5-A7) | 8 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 165 | EF3-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN - START / STOP - CT (TYP. 8) | AHU3-3 ---- EF3-10C (LOCATED COLUMN 1.3-4.7) AHU3-4 ---- EF3-10D (LOCATED AT AHU3-4) | | 8 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 166 | EF3-6, 6A, 7, 9,10A, 10B, 10C, 10D, | EXHAUST FAN DAMPER ACTUATOR (TYP. 8) | AHU3-5 ---- EF1-11 (LOCATED T COLUMN 8H) EF3-6 TOILETS EF3-6A TOILETS EF3-7 TOILETS | | | | 8 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 167 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 1 - SMOKE ZONE 3 - UPPER LEVEL LOUNG - 3U-E03 | BLDG. 3 | | 1 | | | DO | FURNISH AND INSTALL NEW ELECTRONIC DAMPER ACTUATORS. EXTEND WIRING FROM NEW CONTROLLER TO NEW ACTUATOR AND COMMISSION AS SPECIFIED IN SECTIONS 230923 AND 230999. (TYP. SMOKE DAMPER 1 THRU 11). | % OPEN |
| 168 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 2 - SMOKE ZONE 3 - INMATE ROOMS E | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 169 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 3 - SMOKE ZONE 2 - LOWER LOUNGE 3L-E02 | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 170 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 4 - SMOKE ZONE 2 - LOWER LOUNGE 3U-E02 | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 171 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 5 - AHU3-4 - RETURN DUCT FROM INMATE RROOM D AND CORRIDOR - EXHAUST DAMPER LOCATED AT AHU | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 172 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 6 - AHU3-4 EXHAUST DAMPER LOCATED AT AHU (EF3-10-0) | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 173 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 7 - SMOKE ZONE 1 - LOUNGE 3U-E02 | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 174 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 8 - SMOKE ZONE 2 - LOWER LOUNGE 3L-E02 | BLDG. 3 | | 1 | | | DO | | SMOKE PURGE ZONE 1 - UPPER LEVEL LOUNGE 3U-E03 |
| 175 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 9 - SUPPLY DUCT TO CORRIDOR | BLDG. 3 | | 1 | | | DO | | SMOKE PURGE ZONE 2 - LOWER LEVEL LOUNG 3L-E02 |
| 176 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 10 - SUPPLY DUCT TO INMATE ROOM D | BLDG. 3 | | 1 | | | DO | | SMOKE PURGE ZONE 3 - INMATE ROOMS E |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|--|--|--------|----|----|----|-----------------------|--|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 177 | SMOKE PURGE - AHU3-4 (ONLY) | SMK DAMPER 11 - AHU3-4 - RETURN DUCT FROM ZONES 1, 2, 3 CORRIDOR, INMATE RMS D | BLDG. 3 | | 1 | | | DO | | % OPEN |
| 178 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 179 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 180 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 181 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 182 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 183 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 184 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 185 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 186 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 187 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 188 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 189 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 190 | CP-HT-3 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 191 | | | | | | | | | | |
| 192 | CP-4-4-1, 2, 3 (TYP OF 3.) | AHU4-1, 2, 3 (TYP. OF 3) | BLDG. 4 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 193 | | OUTDOOR AIR DAMPER | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 194 | | MIXED AIR DAMPER | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 195 | | FILTER STATUS | AHU4-1, 2, 3 (TYP.) | 3 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 196 | | MIXED AIR TEMPERATURE SENSOR | AHU4-1, 2, 3 (TYP.) | | | 3 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 197 | | SUPPLY FAN START/STOP | AHU4-1, 2, 3 (TYP.) | | 3 | | | DO | F/I CT - HAWKEYE | ON/OFF |
| 198 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU4-1, 2, 3 (TYP.) | 3 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 199 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU4-1, 2, 3 (TYP.) | 3 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 200 | | EXHAUST FAN - START / STOP - CT | AHU4-1, 2, 3 (TYP.) | | 3 | | | DI | F/I CT - HAWKEYE | STATUS - ON/OFF |
| 201 | | EXHAUST FAN DAMPER ACTUATOR | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 202 | | HOT DECK VALVE | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 203 | | COLD DECK VALVE | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 204 | | HOT DECK SUPPLY TEMP | AHU4-1, 2, 3 (TYP.) | | | 3 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 205 | | COLD DECK SUPPLY TEMP | AHU4-1, 2, 3 (TYP.) | | | 3 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 206 | | RETURN HUMIDITY | AHU4-1, 2, 3 (TYP.) | | | 3 | | AI | F/I SENSOR | % HUM / HI HUM |
| 207 | | RETURN TEMP | AHU4-1, 2, 3 (TYP.) | | | 3 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 208 | | ZONE 1 RETURN TEMP | AHU4-1, 2, (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 209 | | ZONE 2 RETURN TEMP | AHU4-1, 2, (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 210 | | ZONE 3 RETURN TEMP | AHU4-1, 2, (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 211 | | ZONE 4 RETURN TEMP | AHU4-1, 2, (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 212 | | ZONE 5 RETURN TEMP | AHU4-1, 2, (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 213 | | ZONE 6 RETURN TEMP | AHU4-1, 2, (TYP.) | | | 2 | | AI | F/I SENSOR | DEG. F / HI TEMP |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|--|--|--------|----|----|----|-----------------------|--|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 6 | | | | | | | | | | |
| 214 | | ZONE 1 DAMPER | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 215 | | ZONE 2 DAMPER | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 216 | | ZONE 3 DAMPER | AHU4-1, 2, 3 (TYP.) | | | | 3 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 217 | | ZONE 4 DAMPER | AHU4-1, 2, (TYP.) | | | | 2 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 218 | | ZONE 5 DAMPER | AHU4-1, 2, (TYP.) | | | | 2 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 219 | | ZONE 6 DAMPER | AHU4-1, 2, (TYP.) | | | | 2 | AO | F/I DAMPER ACTUATOR | % OPEN |
| 220 | | TU4-1 | GROUP ROOM 4-108 | | | | | N/A | REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT CONTROLLER. FURNISH AND INSTALL (F/I) NEW ELECTRONIC REHEAT VALVES. F/I WIRING TO REHEAT VALVE. REPLACE EXISTING WALL SENSOR AS INDICATED. EXTEND NEW CONTROLLER COMMUNICATION SUBNETWORK CONNECTED TO NEAREST MASTER (IP LEVEL) CONTROLLER. | |
| 221 | | TU4-2 | INMATE PROPERTY 4-120 | | | | | N/A | | |
| 222 | | TU4-3 | GROUP ROOM 4-105 | | | | | N/A | | |
| 223 | | TU4-3-2 | CENTRAL CLINIC 4-158 | | | | | N/A | | |
| 224 | | TU4-3-3 | CONFERENCE 4-145 | | | | | N/A | | |
| 225 | | TU4-4 | PHARMACY 4-122 | | | | | N/A | | |
| 226 | | TU4-5 | SOCIAL WORKER 4-105 | | | | | N/A | | |
| 227 | | TU4-6 | CORRIDOR 4-159 | | | | | N/A | | |
| 228 | | TU4-7 | HEAD NURSE 4-157 | | | | | N/A | | |
| 229 | | TU4-8 | LAB 4-151 | | | | | N/A | | |
| 230 | | TU4-9 | MN SURGUERY 4-149 | | | | | N/A | | |
| 231 | | TU4-10 | EXAM 3 4-125 | | | | | N/A | | |
| 232 | | TU4-11 | EXAM 4 4-128 | | | | | N/A | | |
| 233 | | TU4-12 | EXAM CORRIDOR 4-139A | | | | | N/A | | |
| 234 | | TU4-13 | DR. OFF. #4 4-131 | | | | | N/A | | |
| 235 | | TU4-14 | HEAD PHYCH NURSE 4-134 | | | | | N/A | | |
| 236 | | TU4-15 | MENTAL HEALTH DR. 4-144 | | | | | N/A | | |
| 237 | | TU4-17 | HEALTH SERVICE DR. 4-148 | | | | | N/A | | |
| 238 | | MANUAL EF FAN CONTROL PANEL LOCATED AT NURSES STATION (TYP. 6) | THIS SYSTEM WILL REMAIN IN PLACE. REPLACE PNUEMATIC OUTPUT FROM THE PANEL RELAY TO THE DAMPER ACTUATOR. REPLACE THE EXISTING PNUEMATIC ACTUATOR WITH AN ELECTRONIC ACTUATOR. | | | | | | | |
| 239 | | EF4-9 MANUAL CONTROL | ROOM 4-901 | 1 | 1 | | 1 | | REPLACE THE EXISTING PNEUMATIC DAMPER ACTUATOR WITH A NEW ELECTRONIC ACTUATOR. EXTEND WIRING FROM THE EXISTING RELAY TO NEW DAMPER. | |
| 240 | | EF4-10 MANUAL CONTROL | ROOM 4-902 | 1 | 1 | | 1 | | | |
| 241 | | EF4-11 MANUAL CONTROL | ROOM 4-903 | 1 | 1 | | 1 | | | |
| 242 | | EF4-12 MANUAL CONTROL | ROOM 4-904 | 1 | 1 | | 1 | | | |
| 243 | | EF4-13 MANUAL CONTROL | ROOM 4-905 | 1 | 1 | | 1 | | | |
| 244 | | EF4-14 MANUAL CONTROL | ROOM 4-906 | 1 | 1 | | 1 | | | |
| 245 | EF4-3, 7, 8 | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 8) | AHU4-1 ----EF4-7 (LOC.ATED AT AHU) | 3 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 246 | EF4-3, 7, 8 | EXHAUST FAN - START / STOP - CT (TYP. 8) | AHU4-2 ----EF4-8 (LOCATED AT UNIT) | | 3 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 247 | EF4-3, 7, 8 | EXHAUST FAN DAMPER ACTUATOR (TYP. 8) | AHU4-3 ---- EF4-3 (LOCATED AT UNIT) NOTE - EF4-3 AND SF OF UNIT SERVED BY EXISTING | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 248 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 249 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 250 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 251 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 252 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 253 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 254 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 255 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | DEG. F / BTU |
| 256 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | GPM / BTU |
| 257 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|--------------------------|---|---|--|--------|----|----|--------|--|--------------------|
| | 6 | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | POINTS | | | | PROTOCOL / POINT TYPE | SCOPE |
| DI | | | | | DO | AI | AO | | | |
| 258 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 259 | | HOT WATER DIFFRENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW DEVICE WITHIN THE MAIN BUILDING MER / WATER SERVICE ENTRANCE | PSI |
| 260 | CP-HT-4 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNCATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 261 | | | | | | | | | | |
| 262 | CP-5-AHU5-1 | AHU5-1 | BLDG. 5 GYMNASIUM MECHANICAL MEZZ | | | | | BACnet | FURNISH AND INTALL A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 263 | | OUTDOOR AIR DAMPER | AHU5-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 264 | | MIXED AIR DAMPER | AHU5-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 265 | | FILTER STATUS | AHU5-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 266 | | MIXED AIR TEMPERATURE SENSOR | AHU5-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 267 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU5-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 268 | | SUPPLY FAN - START / STOP - CT | AHU5-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON/OFF |
| 269 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU5-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 270 | | EXHAUST FAN - START / STOP - CT | AHU5-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 271 | | EXHAUST FAN DAMPER ACTUATOR | AHU5-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 272 | | HOT DECK VALVE | AHU5-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 273 | | COLD DECK VALVE | AHU5-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 274 | | HOT DECK SUPPLY TEMP | AHU5-1 | | | 1 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 275 | | COLD DECK SUPPLY TEMP | AHU5-1 | | | 1 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 276 | | RETURN HUMIDITY | AHU5-1 | | | 1 | | AI | F/I SENSOR | % HUM / HI HUM |
| 277 | | RETURN TEMP | AHU5-1 | | | 1 | | AI | F/I SENSOR | DEG. F / HI TEMP |
| 278 | | AHU5-1 VFD - START / STOP | AHU5-1 | | 1 | | | DO | | COMMAND |
| 279 | | AHU5-1 VFD - STATUS | AHU5-1 | 1 | | | | DI | | STATUS ON / OFF |
| 280 | | | | | | | | | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | |
| 281 | | AHU5-1 VFD - SPEED CONTROL | AHU5-1 | | | | 1 | AO | | SPEED OUIPUT |
| 282 | | AHU5-1 VFD - SPEED READING | AHU5-1 | | | 1 | | AI | | SPEED READING |
| 283 | | AHU4-3 STATIC PRESSURE SENSOR | AHU4-3 | | | | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 284 | EF5-1,2,4 | EXHAUST FAN - STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU5-1 ----EF5-1 (LOC.ATED AT AHU) | 3 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 285 | EF5-1,2,4 | EXHAUST FAN - START / STOP - CT | EF5-2 TOILETS | | 3 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 286 | EF5-1,2,4 | EXHAUST FAN DAMPER ACTUATOR | EF5-4 --- MECH ROOM 5-118 NOTE: AHU5-1 SF SERVED BY EXISTING VFD | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 287 | EF5-1, 2, 4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU5-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 288 | EF5-1, 2, 4 | EXHAUST FAN - START / STOP - CT | AHU5-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 289 | EF5-1, 2, 4 | EXHAUST FAN DAMPER ACTUATOR | AHU5-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 290 | FCU-5-1, 2, 3, 4 (TYP 4) | SUPPLY AIR TEMP | FCU-5-1, 2, 3, 4 (TYP 4) | | | 4 | | AI | F/I NEW DAMPER ACTUATOR | DEG. F / HI TEMP |
| 291 | FCU-5-1, 2, 3, 4 (TYP 4) | MIXED AIR TEMP | FCU-5-1, 2, 3, 4 (TYP 4) | | | 4 | | AI | F/I NEW TEMP SENSOR | DEG. F / HI TEMP |
| 292 | FCU-5-1, 2, 3, 4 (TYP 4) | FREEZ STATS | FCU-5-1, 2, 3, 4 (TYP 4) | 4 | | | | DI | F/I NEW FREEZSTAT | STATUS |
| 293 | FCU-5-1, 2, 3, 4 (TYP 4) | FILTER STATUS | FCU-5-1, 2, 3, 4 (TYP 4) | 4 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE SWITCH | STATUS |
| 294 | FCU-5-1, 2, 3, 4 (TYP 4) | FAN START / STOP | FCU-5-1, 2, 3, 4 (TYP 4) | | 4 | | | DO | F/I NEW CT FOR S/S | CONTROL |
| 295 | FCU-5-1, 2, 3, 4 (TYP 4) | FAN STATUS | FCU-5-1, 2, 3, 4 (TYP 4) | 4 | | | | DI | F/I NEW CT FOR STATUS | ON / OFF |
| 296 | FCU-5-1, 2, 3, 4 (TYP 4) | OUTDOOR AIR DAMPER | FCU-5-1, 2, 3, 4 (TYP 4) | | | | 4 | AO | F/I NEW DAMPER ACTUATOR - EXISTING DAMPER TO REMAIN | % OPEN |
| 297 | FCU-5-1, 2, 3, 4 (TYP 4) | COOLING COIL VALVE | FCU-5-1, 2, 3, 4 (TYP 4) | | | | 4 | AO | F/I NEW COOLING VALVE | % OPEN |
| 298 | FCU-5-1, 2, 3, 4 (TYP 4) | HEATING COIL VALVE | FCU-5-1, 2, 3, 4 (TYP 4) | | | | 4 | AO | F/I NEW HEATING VALVE | % OPEN |
| 299 | | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 300 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 301 | MAIN BUILDING MER | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|--|---|---|----|----|----|----|-----------------------|--|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 302 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 303 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 304 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 305 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 306 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 307 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 308 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 309 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 310 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 311 | CP-HT-5 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 312 | | | | | | | | | | |
| 313 | CP-6--1 | AHU6-1 | BLDG. 6 GYMNASIUM MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 314 | | OUTDOOR AIR DAMPER | AHU6-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 315 | | MIXED AIR DAMPER | AHU6-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 316 | | FILTER STATUS | AHU6-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 317 | | MIXED AIR TEMPERATURE SENSOR | AHU6-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 318 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU6-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 319 | | SUPPLY FAN - START / STOP - CT | AHU6-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON/OFF |
| 320 | EF6-4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU6-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 321 | EF6-4 | EXHAUST FAN - START / STOP - CT | AHU6-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 322 | EF6-4 | EXHAUST FAN DAMPER ACTUATOR | AHU6-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 323 | | HOT WATER VALVE | AHU6-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 324 | | CHILLED WATER VALVE | AHU6-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 325 | | RETURN HUMIDITY | AHU6-1 | | | 1 | | AI | F/I SENSOR | % HUM / HI HUM |
| 326 | | AHU6-1 VFD - START / STOP | AHU6-1 | | 1 | | | DO | | COMMAND |
| 327 | | AHU6-1 VFD - STATUS | AHU6-1 | 1 | | | | DI | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | STATUS ON / OFF |
| 328 | | AHU6-1 VFD - SPEED CONTROL | AHU6-1 | | | 1 | | AO | | SPEED OUIPUT |
| 329 | | AHU6-1 VFD - SPEED READING | AHU6-1 | | | 1 | | AI | | SPEED READING |
| 330 | | AHU6-1 STATIC PRESSURE SENSOR | AHU6-1 | | | | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 331 | | SUPPLY AIR SMOKE DETECTOR | AHU6-1 | 1 | | | | | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 332 | | RETURN AIR SMOKE DETECTOR | AHU6-1 | 1 | | | | | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 333 | | TU6-1 | COUNSELOR 6-108 | | | | | | TU-1 THROUGH 16: REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT CONTROLLER. EXISTING REHEAT VALVES SHALL REMAIN AND BE REUSED. F/I WIRING TO EXISTING VALVE. REPLACE EXISTING WALL SENSOR AS INDICATED IN NOTES SECTION | |
| 334 | | TU6-2 | COUNSELOR 6-109 | | | | | | | |
| 335 | | TU6-3 | COUNSELOR 6-116 | | | | | | | |
| 336 | | TU6-4 | TESTING CLASSROOM 6-145 | | | | | | | |
| 337 | | TU6-5 | INMATE WAITING 6-144 | | | | | | | |
| 338 | | TU6-6 | TESTING CLASSROOM 6-147 | | | | | | | |
| 339 | | TU6-8 | SECRETARY 6-121 | | | | | | | |
| 340 | | TU6-9 | D. WARDEN PROGRAMS 6-122 | | | | | | | |
| 341 | | TU6-10 | D. WARDEN OPS. 6-124 | | | | | | | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|---|--------|----|----|----|--------|--|--------------------|
| | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | | | |
| 6 | | | | | | | | | | |
| 342 | | TU6-11 | ASSEMBLY (NORTH) 6-101 | | | | | | RELEASE EXISTING WALL SENSOR AS INDICATED IN NOTES SECTION. EXTEND NEW CONTROLLER COMMUNICATION SUBNETWORK CONNECTED TO NEAREST MASTER (IP LEVEL) CONTROLLER. | |
| 343 | | TU6-12 | ASSEMBLY (SOUTH) 6-101 | | | | | | | |
| 344 | | TU6-13 | SHIFT CAPTAIN 6-102 | | | | | | | |
| 345 | | TU6-14 | CONFERENCE 6-141 | | | | | | | |
| 346 | | TU6-15 | WORK AREA 6-137 | | | | | | | |
| 347 | | TU6-16 | INMATE RECORDS 6-135 | | | | | | | |
| 348 | EF6-2 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU6-2 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 349 | EF6-2 | EXHAUST FAN - START / STOP - CT | AHU6-2 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 350 | EF6-2 | EXHAUST FAN DAMPER ACTUATOR | AHU6-2 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 351 | EF6-4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF6-4 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 352 | EF6-4 | EXHAUST FAN - START / STOP - CT | EF6-4 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 353 | EF6-4 | EXHAUST FAN DAMPER ACTUATOR | EF6-4 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 354 | EF6-4 | INTAKE FAN DAMPER ACTUATOR | EF6-4 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 355 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 356 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 357 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 358 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 359 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 360 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 361 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 362 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 363 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 364 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 365 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 366 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 367 | CP-HT-6 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 368 | | | | | | | | | | |
| 369 | <u>CP-7-1</u> | AHU7-1 | BLDG. 7 GYMNASIUM | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 370 | | OUTDOOR AIR DAMPER | AHU7-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 371 | | MIXED AIR DAMPER | AHU7-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 372 | | FILTER STATUS | AHU7-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 373 | | MIXED AIR TEMPERATURE SENSOR | AHU7-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 374 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU7-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 375 | | SUPPLY FAN - START / STOP - CT | AHU7-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 376 | EF7-4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU7-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 377 | EF7-4 | EXHAUST FAN - START / STOP - CT | AHU7-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 378 | EF7-4 | EXHAUST FAN DAMPER ACTUATOR | AHU7-1 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 379 | | HOT WATER VALVE | AHU7-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|--|---|--|----|----|----|----|-----------------------|--|----------------------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 6 | | | | | | | | | | |
| 380 | | CHILLED WATER VALVE | AHU7-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 381 | | RETURN HUMIDITY | AHU7-1 | | | 1 | | AI | F/I SENSOR | % HUM / HI HUM |
| 382 | | AHU7-1 VFD - START / STOP | AHU7-1 | | 1 | | | DO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | COMMAND |
| 383 | | AHU7-1 VFD - STATUS | AHU7-1 | 1 | | | | DI | | STATUS ON / OFF |
| 384 | | AHU7-1 VFD - SPEED CONTROL | AHU7-1 | | | | 1 | AO | | SPEED OUIPUT |
| 385 | | AHU7-1 VFD - SPEED READING | AHU7-1 | | | 1 | | AI | | SPEED READING |
| 386 | | SUPPLY AIR SMOKE DETECTOR | AHU7-1 | 1 | | | | DI | | WIRE TO EXISTING SMOKE DETECTOR. |
| 387 | | RETURN AIR SMOKE DETECTOR | AHU7-1 | 1 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 388 | FCU7-1, 2,(TYP.) | SUPPLY AIR TEMP | FCU7-1, 2,(TYP.) | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 389 | FCU7-1, 2,(TYP.) | MIXED AIR TEMP | FCU7-1, 2,(TYP.) | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 390 | FCU7-1, 2,(TYP.) | FREEZ STATS | FCU7-1, 2,(TYP.) | 2 | | | | DI | F/I NEW SENSOR | STATUS |
| 391 | FCU7-1, 2,(TYP.) | FILTER STATUS | FCU7-1, 2,(TYP.) | 2 | | | | DI | F/I NEW SWITCH | STATUS |
| 392 | FCU7-1, 2,(TYP.) | FAN START / STOP | FCU7-1, 2,(TYP.) | 2 | | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 393 | FCU7-1, 2,(TYP.) | FAN STATUS | FCU7-1, 2,(TYP.) | | 2 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 394 | FCU7-1, 2,(TYP.) | OUTDOOR AIR DAMPER | FCU7-1, 2,(TYP.) | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | DEG. F / HI TEMP |
| 395 | FCU7-1, 2,(TYP.) | COOLING COIL VALVE | FCU7-1, 2,(TYP.) | | | | 2 | AO | F/I NEW COOLING VALVE | % OPEN |
| 396 | FCU7-1, 2,(TYP.) | HEATING COIL VALVE | FCU7-1, 2,(TYP.) | | | | 2 | AO | F/I NEW HEATING VALVE | % OPEN |
| 397 | | | | | | | | | | |
| 398 | CP-7-2 | MAU7-1 | BLDG. 7 | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS | CONTROLLER OFFLINE |
| 399 | MAU7-1 | OUTDOOR AIR DAMPER | AHU7-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 400 | MAU7-1 | MIXED AIR DAMPER | AHU7-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 401 | MAU7-1 | FILTER STATUS | AHU7-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 402 | MAU7-1 | MIXED AIR TEMPERATURE SENSOR | AHU7-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 403 | MAU7-1 | MAU7-1 SMOKE DETECTOR | MAU7-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 404 | MAU7-1 | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU7-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 405 | MAU7-1 | SUPPLY FAN - START / STOP - CT | AHU7-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 406 | EF7-2, 3, 4, 5 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF7-2, 3, 4, 5 | 4 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 407 | EF7-2, 3, 4, 5 | EXHAUST FAN - START / STOP - CT | EF7-2, 3, 4, 5 | | 4 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 408 | EF7-2, 3, 4, 5 | EXHAUST FAN DAMPER ACTUATOR | EF7-2, 3, 4, 5 | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 409 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 410 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 411 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 412 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 413 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 414 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 415 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 416 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 417 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 418 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 419 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 420 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 421 | CP-HT-7 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNCATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 422 | | | | | | | | | | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|------------------|--|--|--------|----|----|----|-----------------------|---|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 423 | CP-8-1 | AHU8-1 | BLDG. 8 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 424 | | OUTDOOR AIR DAMPER | AHU8-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 425 | | MIXED AIR DAMPER | AHU8-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 426 | | FILTER STATUS | AHU8-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 427 | | MIXED AIR TEMPERATURE SENSOR | AHU8-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 428 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU8-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 429 | | SUPPLY FAN - START / STOP - CT | AHU8-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 430 | EF8-4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU8-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 431 | EF8-4 | EXHAUST FAN - START / STOP - CT | AHU8-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 432 | EF8-4 | EXHAUST FAN DAMPER ACTUATOR | AHU8-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 433 | | HOT WATER VALVE | AHU8-1 | | | | 6 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 434 | | CHILLED WATER VALVE | AHU8-1 | | | | 6 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 435 | | RETURN HUMIDITY | AHU8-1 | | | 6 | | AI | F/I SENSOR | % HUM / HI HUM |
| 436 | | AHU7-1 VFD - START / STOP | AHU8-1 | | 1 | | | DO | | COMMAND |
| 437 | | AHU7-1 VFD - STATUS | AHU8-1 | 1 | | | | DI | | STATUS ON / OFF |
| 438 | | AHU7-1 VFD - SPEED CONTROL | AHU8-1 | | | | 1 | AO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | SPEED OUIPUT |
| 439 | | AHU7-1 VFD - SPEED READING | AHU8-1 | | | 1 | | AI | | SPEED READING |
| 440 | | SUPPLY AIR SMOKE DETECTOR | AHU8-1 | 1 | | | | | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 441 | | AHU8-1 STATIC PRESSURE SENSOR | AHU8-1 | | | 1 | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 442 | | RETURN AIR SMOKE DETECTOR | AHU8-1 | 1 | | | | | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 443 | FCU8-1, 2,(TYP.) | SUPPLY AIR TEMP | FCU8-1, 2,(TYP.) | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 444 | FCU8-1, 2,(TYP.) | MIXED AIR TEMP | FCU8-1, 2,(TYP.) | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 445 | FCU8-1, 2,(TYP.) | FREEZ STATS | FCU8-1, 2,(TYP.) | 2 | | | | DI | F/I NEW SENSOR | STATUS |
| 446 | FCU8-1, 2,(TYP.) | FILTER STATUS | FCU8-1, 2,(TYP.) | 2 | | | | DI | F/I NEW PRESSURE DIFFERENTIAL SWITCH | STATUS |
| 447 | FCU8-1, 2,(TYP.) | FAN START / STOP | FCU8-1, 2,(TYP.) | | 2 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 448 | FCU8-1, 2,(TYP.) | FAN STATUS | FCU8-1, 2,(TYP.) | 2 | | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 449 | FCU8-1, 2,(TYP.) | OUTDOOR AIR DAMPER | FCU8-1, 2,(TYP.) | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | DEG. F / HI TEMP |
| 450 | FCU8-1, 2,(TYP.) | COOLING COIL VALVE | FCU8-1, 2,(TYP.) | | | | 2 | | F/I NEW COOLING VALVE | % OPEN |
| 451 | FCU8-1, 2,(TYP.) | HEATING COIL VALVE | FCU8-1, 2,(TYP.) | | | | 2 | | F/I NEW HEATING VALVE | % OPEN |
| 452 | MAU8-1 | OUTDOOR AIR DAMPER | AHU8-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 453 | MAU8-1 | MIXED AIR DAMPER | AHU8-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 454 | MAU8-1 | FILTER STATUS | AHU8-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 455 | MAU8-1 | MIXED AIR TEMPERATURE SENSOR | AHU8-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 456 | MAU8-1 | MAU7-1 SMOKE DETECETOR | AHU8-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 457 | MAU8-1 | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU8-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 458 | MAU8-1 | SUPPLY FAN - START / STOP - CT | AHU8-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 459 | EF8-2, 3, 4, 5 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF8-2, 3, 4, 5 | 4 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 460 | EF8-2, 3, 4, 5 | EXHAUST FAN - START / STOP - CT | EF8-2, 3, 4, 5 | | 4 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 461 | EF8-2, 3, 4, 5 | EXHAUST FAN DAMPER ACTUATOR | EF8-2, 3, 4, 5 | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 462 | | TU8-1 | CHAPEL 137 | | | | | MSTP | | |
| 463 | | TU8-2 | CHAPEL 137 | | | | | MSTP | | |
| 464 | | TU8-3 | FISCAL CLERK 167 | | | | | MSTP | | |
| 465 | | TU8-4 | SECRETARY 162 | | | | | MSTP | TU-1 THROUGH TU-17: REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT CONTROLLER. | |
| 466 | | TU8-5 | WARDEN 161 | | | | | MSTP | | |
| 467 | | TU8-6 | WARDEN CONFERENCE 160 | | | | | MSTP | EXISTING REHEAT VALVES SHALL REMAIN AND BE REUSED | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|---|--------|----|----|----|-----------------------|---|---------------------|
| | | | | DI | DO | AI | AO | | | |
| 6 | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | | | | | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 468 | | TU8-8 | BUSINESS MANAGGER 140 | | | | | MSTP | EXISTING RETURN VALVES SHALL REMAIN AND BE REUSED. F/I WIRING TO EXISTING VALVE. REPLACE EXISTING WALL SENSOR AS INDICATED IN NOTES SECTION. EXTEND NEW CONTROLLER COMMUNICATION SUBNETWORK CONNECTED TO NEAREST MASTER (IP LEVEL) CONTROLLER. | |
| 469 | | TU8-10 | WAITING 100 | | | | | MSTP | | |
| 470 | | TU8-12 | VISITATION 114 | | | | | MSTP | | |
| 471 | | TU8-13 | ATTORNEY/CLIENT 111 | | | | | MSTP | | |
| 472 | | TU8-14 | VISITATION 114 | | | | | MSTP | | |
| 473 | | TU8-15 | VISITATION 114 | | | | | MSTP | | |
| 474 | | TU8-17 | GUARD STATION 119 | | | | | MSTP | | |
| 475 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 476 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 477 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 478 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 479 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 480 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 481 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 482 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 483 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 484 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 485 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 486 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 487 | CP-HT-8 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 488 | | | | | | | | | | |
| 489 | <u>CP-9A-1, 2 (TYP. OF 2)</u> | AHU9A-1, 2 (TYP. OF 2) | BLDG. 9A MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 490 | | | | | | | | | | |
| 491 | | OUTDOOR AIR DAMPER | AHU9A-1, 2 (TYP) | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 492 | | MIXED AIR DAMPER | AHU9A-1, 2 (TYP) | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 493 | | FILTER STATUS | AHU9A-1, 2 (TYP) | 2 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 494 | | MIXED AIR TEMPERATURE SENSOR | AHU9A-1, 2 (TYP) | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 495 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU9A-1, 2 (TYP) | 2 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 496 | | SUPPLY FAN - START / STOP - CT | AHU9A-1, 2 (TYP) | | 2 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 497 | | HOT WATER VALVE | AHU9A-1, 2 (TYP) | | | | 2 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 498 | | CHILLED WATER VALVE | AHU9A-1, 2 (TYP) | | | | 2 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 499 | | RETURN HUMIDITY | AHU9A-1, 2 (TYP) | | | 2 | | AI | F/I SENSOR | % HUM / HI HUM |
| 500 | | AHU9A-1 VFD - START / STOP | AHU9A-1, 2 (TYP) | | 1 | | | DO | | COMMAND |
| 501 | | AHU9A-1 VFD - STATUS | AHU9A-1, 2 (TYP) | 1 | | | | DI | | STATUS ON / OFF |
| 502 | | AHU9A-1 VFD - SPEED CONTROL | AHU9A-1, 2 (TYP) | | | | 1 | AO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | SPEED OUIPUT |
| 503 | | AHU9A-1 VFD - SPEED READING | AHU9A-1, 2 (TYP) | | | 1 | | AI | | SPEED READING |
| 504 | | AHU9A-1 VFD - BYPASS CONTACT | AHU9A-1, 2 (TYP) | | | | | N/A | | STATUS |
| 505 | | AHU9A-1 STATIC PRESSURE SENSOR | AHU9A-1, 2 (TYP) | | | | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 506 | | SUPPLY AIR SMOKE DETECTOR | AHU9A-1, 2 (TYP) | 1 | | | | AI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|--|---|--|--------|----|----|---|-----------------------|--|----------------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | POINTS | | | | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| DI | | | | DO | AI | AO | | | | |
| 507 | | RETURN AIR SMOKE DETECTOR | AHU9A-1, 2 (TYP) | 1 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 508 | | TU9A-1 | STADD DINING 9A-101 | | | | | MSTP | REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT | |
| 509 | | TU9A-2 | STADD DINING 9A-100 | | | | | MSTP | CONTROLLERS. | |
| 510 | HX9A-1 | HOT WATER BYPASS VALVE - BUILDING SIDE | HX9A-1 | | | | 1 | AO | FURNISH ONLY VALVE. INSTALLED NY MECHANICAL | % OPEN |
| 511 | HX9A-1 | HOT WATER DIFFERENTIAL PRESSURE | HX9A-1 | | | 1 | | AI | F/1 NEW SENSOR | DIFF. PRES. / OUT OF RANGE |
| 512 | HX9A-1 | HOT WATER SUPPLY TEMPERATURE | HX9A-1 | | | 1 | | AI | F/1 NEW SENSOR | DEG. F / HI TEMP |
| 513 | HX9A-1 | HOT WATER RETURN TEMPERATURE | HX9A-1 | | | 1 | | AI | F/1 NEW SENSOR | DEG. F / HI TEMP |
| 514 | HX9A-1 | HOT WATER BYPASS VALVE - MTHW LOOP SIDE | HX9A-1 | | | | 1 | AO | FURNISH ONLY VALVE. INSTALLED BY MECHANICAL | % OPEN |
| 515 | HX9A-1 | HOT WATER PUMP SET COMMON ALARM | HX9A-1 | 1 | | | | DI | WIRE TO DRY CONTACT. PROVIDE ALARM AT BMS | NORMAL / ALARM |
| 516 | FCU9A-1, 2,(TYP.) | SUPPLY AIR TEMP | FCU9A-1, 2,(TYP.) | | | 2 | | AI | F/1 NEW SENSOR | DEG. F / HI TEMP |
| 517 | FCU9A-1, 2,(TYP.) | MIXED AIR TEMP | FCU9A-1, 2,(TYP.) | | | 2 | | AI | F/1 NEW SENSOR | DEG. F / HI TEMP |
| 518 | FCU9A-1, 2,(TYP.) | FREEZ STATS | FCU9A-1, 2,(TYP.) | 2 | | | | DI | F/1 NEW SENSOR | STATUS |
| 519 | FCU9A-1, 2,(TYP.) | FILTER STATUS | FCU9A-1, 2,(TYP.) | 2 | | | | DI | F/1 NEW DIFFERENTIAL PRESSURE SWITCH | STATUS |
| 520 | FCU9A-1, 2,(TYP.) | FAN START / STOP | FCU9A-1, 2,(TYP.) | | 2 | | | DO | F/1 CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 521 | FCU9A-1, 2,(TYP.) | FAN STATUS | FCU9A-1, 2,(TYP.) | 2 | | | | DI | F/1 CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 522 | FCU9A-1, 2,(TYP.) | OUTDOOR AIR DAMPER | FCU9A-1, 2,(TYP.) | | | | 2 | AO | F/1 NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 523 | FCU9A-1, 2,(TYP.) | COOLING COIL VALVE | FCU9A-1, 2,(TYP.) | | | | 2 | AO | F/1 NEW COOLING VALVE | % OPEN |
| 524 | FCU9A-1, 2,(TYP.) | HEATING COIL VALVE | FCU9A-1, 2,(TYP.) | | | | 2 | AO | F/1 NEW HEATING VALVE | % OPEN |
| 525 | MAU9A-1,2,3,4,5 | OUTDOOR AIR DAMPER | MAU9A-1,2,3,4,5 | | | | 5 | AO | F/1 NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 526 | MAU9A-1,2,3,4,5 | MIXED AIR DAMPER | MAU9A-1,2,3,4,5 | | | | 5 | AO | F/1 NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 527 | MAU9A-1,2,3,4,5 | FILTER STATUS | MAU9A-1,2,3,4,5 | 5 | | | | DI | F/1 NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 528 | MAU9A-1,2,3,4,5 | MIXED AIR TEMPERATURE SENSOR | MAU9A-1,2,3,4,5 | | | 5 | | AI | F/1 NEW SENSOR | DEG. F / HI TEMP |
| 529 | MAU9A-1,2,3,4,5 | MAU7-1 SMOKE DETECTOR | MAU9A-1,2,3,4,5 | 5 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 530 | MAU9A-1,2,3,4,5 | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | MAU9A-1,2,3,4,5 | 5 | | | | DI | F/1 NEW SWITCH | STATUS - ON/OFF |
| 531 | MAU9A-1,2,3,4,5 | SUPPLY FAN - START / STOP - CT | MAU9A-1,2,3,4,5 | | 5 | | | DI | F/1 CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 532 | EF9A-7,8,9,10,11 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF9A-7,8,9,10,11 | 5 | | | | DI | F/1 NEW SWITCH | STATUS - ON/OFF |
| 533 | EF9A-7,8,9,10,11 | EXHAUST FAN - START / STOP - CT | EF9A-7,8,9,10,11 | | 5 | | | DI | F/1 CURRENT TRANSDUCER - HAWKEYE | ON / OFF |
| 534 | EF9A-7,8,9,10,11 | EXHAUST FAN DAMPER ACTUATOR | EF9A-7,8,9,10,11 | | | | 5 | AO | F/1 NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 535 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 536 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 537 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 538 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 539 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 540 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 541 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 542 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 543 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 544 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 545 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 546 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/1 NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 547 | CP-HT-9A | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 548 | | | | | | | | | | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|--|---|--------|----|----|----|-----------------------|---|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 549 | CP-9B-1 | AHU9B-1 | BLDG. 9B MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 550 | | OUTDOOR AIR DAMPER | AHU9B-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 551 | | MIXED AIR DAMPER | AHU9B-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 552 | | FILTER STATUS | AHU9B-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 553 | | MIXED AIR TEMPERATURE SENSOR | AHU9B-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 554 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU9B-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 555 | | SUPPLY FAN - START / STOP - CT | AHU9B-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON . OFF |
| 556 | EF9B-1 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU9B-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 557 | EF9B-1 | EXHAUST FAN - START / STOP - CT | AHU9B-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | ON . OFF |
| 558 | EF9B-1 | EXHAUST FAN DAMPER ACTUATOR | AHU9B-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 559 | | HOT WATER VALVE | AHU9B-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 560 | | CHILLED WATER VALVE | AHU9B-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 561 | | RETURN HUMIDITY | AHU9B-1 | | | 1 | | AI | F/I SENSOR | % HUM / HI HUM |
| 562 | | AHU9B-1 VFD - START / STOP | AHU9B-1 | | 1 | | | DO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | COMMAND |
| 563 | | AHU9B-1 VFD - STATUS | AHU9B-1 | 1 | | | | DI | | STATUS ON / OFF |
| 564 | | AHU9B-1 VFD - SPEED CONTROL | AHU9B-1 | | | 1 | | AO | | SPEED OUIPUT |
| 565 | | AHU9B-1 VFD - SPEED READING | AHU9B-1 | | | 1 | | AI | | SPEED READING |
| 566 | | AHU9B-1 VFD - BYPASS CONTACT | AHU9B-1 | | | | | N/A | | STATUS |
| 567 | | AHU9B-1 STATIC PRESSURE SENSOR | AHU9B-1 | | | | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 568 | | SUPPLY AIR SMOKE DETECTOR | AHU9B-1 | 1 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 569 | | RETURN AIR SMOKE DETECTOR | AHU9B-1 | 1 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 570 | | TU9B-1 | LIFE SKILLS 9B-116 | | | | | MSTP | REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT CONTROLLER. EXISTING REHEAT VALVES SHALL REMAIN AND BE REUSED. F/I WIRING TO EXISTING VALVE. REPLACE EXISTING WALL SENSOR AS INDICATED IN NOTES SECTION. EXTEND NEW CONTROLLER COMMUNICATION SUBNETWORK | |
| 571 | | TU9B-2 | COMPUTER LAB 9B-122 | | | | | MSTP | | |
| 572 | | TU9B-3 | VESTIBULE 9B-129 | | | | | MSTP | | |
| 573 | | TU9B-4 | ELECTRONICS 9B-137 | | | | | MSTP | | |
| 574 | | TU9B-7 | PRE-VOCATIONAL 9B-144 | | | | | MSTP | | |
| 575 | | TU9B-17 | SMALL ENGINE 9B-150 | | | | | MSTP | | |
| 576 | | TU9-8 | SMALL ENGINE 9B-151 | | | | | MSTP | | |
| 577 | EF9B-2 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | RM 9B 124 | 1 | | | | DI | | F/I NEW SWITCH |
| 578 | EF9B-2 | EXHAUST FAN - START / STOP - CT | RM 9B 124 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 579 | EF9B-2 | EXHAUST FAN DAMPER ACTUATOR | RM 9B 124 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 580 | EF9B-2 | INTAKE FAN DAMPER ACTUATOR | RM 9B 124 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 581 | EF9B-3 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | RM 9B 135 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 582 | EF9B-3 | EXHAUST FAN - START / STOP - CT | RM 9B 135 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 583 | EF9B-3 | EXHAUST FAN DAMPER ACTUATOR | RM 9B 135 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 584 | EF9B-3 | INTAKE FAN DAMPER ACTUATOR | RM 9B 135 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 585 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 586 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 587 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 588 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|---|--------|----|----|----|--------|--|--------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | | | |
| 589 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 590 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 591 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 592 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 593 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 594 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 595 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 596 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 597 | CP-HT-9B | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 598 | | | | | | | | | | |
| 599 | CP-9C-1, 2, 3, 4 (TYP. OF 4) | AHU9C-1, 2, 3, 4 (TYP. OF 4) | BLDG. 9C MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 600 | | OUTDOOR AIR DAMPER (2) | AHU9C-1, 2, 3, 4 (TYP) | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 601 | | FILTER STATUS | AHU9C-1, 2, 3, 4 (TYP) | 4 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 602 | | MIXED AIR TEMPERATURE SENSOR | AHU9C-1, 2, 3, 4 (TYP) | | | 4 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 603 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU9C-1, 2, 3, 4 (TYP) | 4 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 604 | | SUPPLY FAN - START / STOP - CT | AHU9C-1, 2, 3, 4 (TYP) | | 4 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 605 | EF9C-1 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU9C-1, 2, 3, 4 (TYP) | 4 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 606 | EF9C-1 | EXHAUST FAN - START / STOP - CT | AHU9C-1, 2, 3, 4 (TYP) | | 4 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 607 | EF9C-1 | EXHAUST FAN DAMPER ACTUATOR | AHU9C-1, 2, 3, 4 (TYP) | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 608 | | HOT WATER VALVE | AHU9C-1, 2, 3, 4 (TYP) | | | | 4 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 609 | | CHILLED WATER VALVE | AHU9C-1, 2, 3, 4 (TYP) | | | | 4 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 610 | | RETURN HUMIDITY | AHU9C-1, 2, 3, 4 (TYP) | | | 4 | | AI | F/I SENSOR | % HUM / HI HUM |
| 611 | | AHU9C-1 VFD - START / STOP | AHU9C-1, 2, 3, 4 (TYP) | | 4 | | | DO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | COMMAND |
| 612 | | AHU9C-1 VFD - STATUS | AHU9C-1, 2, 3, 4 (TYP) | 4 | | | | DI | | STATUS ON / OFF |
| 613 | | AHU9C-1 VFD - SPEED CONTROL | AHU9C-1, 2, 3, 4 (TYP) | | | 4 | | AO | | SPEED OUTPUT |
| 614 | | AHU9C-1 VFD - SPEED READING | AHU9C-1, 2, 3, 4 (TYP) | | | 4 | | AI | | SPEED READING |
| 615 | | | | | | | | | | STATUS |
| 616 | | AHU9C-1 STATIC PRESSURE SENSOR | AHU9C-1, 2, 3, 4 (TYP) | | | 4 | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 617 | | SUPPLY AIR SMOKE DETECTOR | AHU9C-1, 2, 3, 4 (TYP) | 4 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 618 | | RETURN AIR SMOKE DETECTOR | AHU9C-1, 2, 3, 4 (TYP) | 4 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 619 | | TU9C-1 | COMPUTER LAB 9C-100 | | | | | MSTP | YU-1 THROUGH 5: | |
| 620 | | TU9C-2 | COMPUTER LAB 9C-110 | | | | | MSTP | REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT CONTROLLER. | |
| 621 | | TU9C-3 | WORK ROOM 9C-134 | | | | | MSTP | | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|--|--------|----|----|----|-----------------------|---|---------------------|
| | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 622 | | TU9C-4 | INMATE BREAK AREA 9C-126 | | | | | MSTP | FURNISH AND INSTALL (F/I) NEW ELECTRONIC REHEAT VALVES. F/I WIRING TO REHEAT VALVE. REPLACE EXISTING WALL SENSOR AS INDICATED IN NOTES SECTION. EXTEND NEW CONTROLLER COMMUNICATION SUBNETWORK CONNECTED TO NEAREST MASTER (IP LEVEL) CONTROLLER. | |
| 623 | | TU9C-5 | INMATE BREAK AREA 9C-127 | | | | | MSTP | | |
| 624 | EF9C-3 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | RM 9C 122A | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 625 | EF9C-3 | EXHAUST FAN - START / STOP - CT | RM 9C 122A | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 626 | EF9C-3 | EXHAUST FAN DAMPER ACTUATOR | RM 9C 122A | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 627 | EF9C-3 | INTAKE FAN DAMPER ACTUATOR | RM 9C 122A | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 628 | EF9C-4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | RM 9C 124 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 629 | EF9C-4 | EXHAUST FAN - START / STOP - CT | RM 9C 124 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 630 | EF9C-4 | EXHAUST FAN DAMPER ACTUATOR | RM 9C 124 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 631 | EF9C-4 | INTAKE FAN DAMPER ACTUATOR | RM 9C 124 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 632 | FCU9C-1, 2,3,4 (TYP.) | SUPPLY AIR TEMP | FCU9C-1, 2,3,4 (TYP.) | | | 4 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 633 | FCU9C-1, 2,3,4 (TYP.) | MIXED AIR TEMP | FCU9C-1, 2,3,4 (TYP.) | | | 4 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 634 | FCU9C-1, 2,3,4 (TYP.) | FREEZ STATS | FCU9C-1, 2,3,4 (TYP.) | 4 | | | | DI | F/I NEW SENSOR | STATUS |
| 635 | FCU9C-1, 2,3,4 (TYP.) | FILTER STATUS | FCU9C-1, 2,3,4 (TYP.) | 4 | | | | DI | F/I NEW PRESSURE DIFFERENTIALSWITCH | STATUS |
| 636 | FCU9C-1, 2,3,4 (TYP.) | FAN START / STOP | FCU9C-1, 2,3,4 (TYP.) | | 4 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 637 | FCU9C-1, 2,3,4 (TYP.) | FAN STATUS | FCU9C-1, 2,3,4 (TYP.) | 4 | | | | DI | F/I NEW SWITCH | ON / OFF |
| 638 | FCU9C-1, 2,3,4 (TYP.) | OUTDOOR AIR DAMPER | FCU9C-1, 2,3,4 (TYP.) | | | 4 | | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | DEG. F / HI TEMP |
| 639 | FCU9C-1, 2,3,4 (TYP.) | COOLING COIL VALVE | FCU9C-1, 2,3,4 (TYP.) | | | 4 | | AO | F/I NEW COOLING VALVE | % OPEN |
| 640 | FCU9C-1, 2,3,4 (TYP.) | HEATING COIL VALVE | FCU9C-1, 2,3,4 (TYP.) | | | 4 | | AO | F/I NEW HEATING VALVE | % OPEN |
| 641 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 642 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 643 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 644 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 645 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 646 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 647 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 648 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 649 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 650 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 651 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 652 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 653 | CP-HT-9C | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 654 | | | | | | | | | | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|---------------------------|---|---|--------|----|----|----|-----------------------|---|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 655 | CP-9D-1, 2, 3 (TYP. OF 3) | AHU9D-1, 2, 3 (TYP. OF 3) | BLDG. 9D MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 656 | | OUTDOOR AIR DAMPER | AHU9D-1, 2, 4 (TYP) | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 657 | | FILTER STATUS | AHU9D-1, 2, 4 (TYP) | 3 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 658 | | SUPPLY AIR TEMPERATURE SENSOR | AHU9D-1, 2, 4 (TYP) | | | 3 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 659 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU9D-1, 2, 4 (TYP) | 3 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 660 | | SUPPLY FAN - START / STOP - CT | AHU9D-1, 2, 4 (TYP) | | 3 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 661 | EF9D-2, 5, 7 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF9D-2, 5, 7 | 3 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 662 | EF9D-2, 5, 7 | EXHAUST FAN - START / STOP - CT | EF9D-2, 5, 7 | | 3 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 663 | EF9D-2, 5, 7 | EXHAUST FAN DAMPER ACTUATOR | EF9D-2, 5, 7 | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 664 | TEF9D-1,2,4,5 | EXHAUST FAN DAMPER ACTUATOR | TEF9D-1,2,4,5 | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 665 | | HOT WATER VALVE | AHU9D-1, 2, 4 (TYP) | | | | 3 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 666 | | AHU9D-1 VFD - START / STOP | AHU9D-1, 2, 4 (TYP) | | 3 | | | DO | | COMMAND |
| 667 | | AHU9D-1 VFD - STATUS | AHU9D-1, 2, 4 (TYP) | 3 | | | | DI | | STATUS ON / OFF |
| 668 | | AHU9D-1 VFD - SPEED CONTROL | AHU9D-1, 2, 4 (TYP) | | | | 3 | AO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | SPEED OUIPUT |
| 669 | | AHU9D-1 VFD - SPEED READING | AHU9D-1, 2, 4 (TYP) | | | 3 | | AI | | SPEED READING |
| 670 | | | | | | | | N/A | | STATUS |
| 671 | | AHU9D-1 STATIC PRESSURE SENSOR | AHU9D-1, 2, 4 (TYP) | | | 3 | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 672 | | SUPPLY AIR SMOKE DETECTOR | AHU9D-1, 2, 4 (TYP) | 3 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 673 | | SUPPLY AIR SMOKE DETECTOR | AHU9D-1 ONLY | 3 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 674 | | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 675 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 676 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 677 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 678 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 679 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 680 | | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 681 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 682 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 683 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 684 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 685 | | HOT WATER DIFFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 686 | CP-HT-9D | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNCATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 687 | | | | | | | | | | |
| 688 | CP-10-1 | AHU10-1 | BLDG. 10 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|-------------------------|---|--|--|--------|----|----|--------|---|--------------------|
| | 6 | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | POINTS | | | | PROTOCOL / POINT TYPE | SCOPE |
| DI | | | | | DO | AI | AO | | | |
| 689 | | OUTDOOR AIR DAMPER | AHU10-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 690 | | FILTER STATUS | AHU10-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE SWITCH | SP - CHNG FLT. |
| 691 | | MIXED AIR TEMPERATURE SENSOR | AHU10-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 692 | | RETURN AIR TEMPERATURE SENSOR | AHU10-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 693 | | SUPPLY AIR TEMPERATURE SENSOR | AHU10-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 694 | | SUPPLY AIR LOW LIMIT SWITCH | AHU10-1 | 1 | | | | DI | F/I NEW SWITCH | NORMAL / ALARM |
| 695 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH | AHU10-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 696 | | SUPPLY FAN - START / STOP - CT | AHU10-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 697 | EF10-1, 2, 3, 6, 7 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 5) | EF10-1, 2, 3, 6, 7 | 5 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 698 | EF10-1, 2, 3, 6, 7 | EXHAUST FAN - START / STOP - CT (TYP. 5) | EF10-1, 2, 3, 6, 7 | | 5 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 699 | EF10-1, 2, 3, 6, 7 | EXHAUST FAN DAMPER ACTUATOR(TYP. 5) | EF10-1, 2, 3, 6, 7 | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 700 | | HOT WATER VALVE | AHU10-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 701 | | CHILLED WATER VALVE | AHU10-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 702 | | SUPPLY AIR SMOKE DETECTOR | AHU10-1 | 1 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 703 | | RETURN AIR SMOKE DETECTOR | AHU10-1 | 1 | | | | DI | WIRE TO EXISTING SMOKE DETECTOR. | STATUS |
| 704 | FCU10-1 | SUPPLY AIR TEMP | FCU10-1 - ROOM 115 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 705 | FCU10-1 | MIXED AIR TEMP | FCU10-1 - ROOM 115 | | | 1 | | AI | F/I NEW SMOKE DETECTOR - COORDINATE WITH FAS PROVIDER | DEG. F / HI TEMP |
| 706 | FCU10-1 | LOW LIMIT SWITCH | FCU10-1 - ROOM 115 | 1 | | | | DI | F/I NEW SWITCH | STATUS |
| 707 | FCU10-1 | FILTER STATUS | FCU10-1 - ROOM 115 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE SWITCH | CLEAN / DIRTY |
| 708 | FCU10-1 | FAN START / STOP | FCU10-1 - ROOM 115 | | 1 | | | DO | F/I NEW CT FOR S/S | CONTROL |
| 709 | FCU10-1 | FAN STATUS | FCU10-1 - ROOM 115 | 1 | | | | DI | F/I NEW CT FOR STATUS | ON / OFF |
| 710 | FCU10-1 | OUTDOOR AIR DAMPER | FCU10-1 - ROOM 115 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 711 | FCU10-1 | COOLING COIL VALVE | FCU10-1 - ROOM 115 | | | | 1 | AO | F/I NEW COOLING VALVE | % OPEN |
| 712 | FCU10-1 | HEATING COIL VALVE | FCU10-1 - ROOM 115 | | | | 1 | AO | F/I NEW HEATING VALVE | % OPEN |
| 713 | | EMERGENCY GENERATOR ROOM COMBUSTION DAMPERS | CENTRAL PLANT - COL. 11-D.8 | | | | | | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 714 | SF10-4, 5, 8, 9, 10, 11 | COMB. INTAKE FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP. 6) | SF10-4, 5, 8, 9, 10, 11 | 6 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 715 | SF10-4, 5, 8, 9, 10, 11 | COMB. INTAKE FAN - START / STOP - CT (TYP. 6) | SF10-4, 5, 8, 9, 10, 11 | | 6 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | STATUS - ON/OFF |
| 716 | SF10-4, 5, 8, 9, 10, 11 | EXHAUST FAN DAMPER ACTUATOR (TYP. 6) | SF10-4, 5, 8, 9, 10, 11 | | | | 6 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 717 | | | | | | | | | | |
| 718 | CP-HT-10 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 719 | | | | | | | | | | |
| 720 | CP-10A | AHU10A-1,2 (TYP. OF 2) | BLDG. 10A UNITS LOCATED ON ROOF REFER TO DRAWING M764 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANELAS SHOWN ON M764 TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 721 | | OUTDOOR AIR DAMPER | AHU10A-1,2 (TYP.) | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 722 | | FILTER STATUS | AHU10A-1,2 (TYP.) | 2 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 723 | | SUPPLY AIR TEMPERATURE SENSOR | AHU10A-1,2 (TYP.) | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 724 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU10A-1,2 (TYP.) | 2 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 725 | | SUPPLY FAN - START / STOP - CT | AHU10A-1,2 (TYP.) | | 2 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 726 | | ROOM TEMP SENSOR | AHU10A-1 - RM 10A-109 AHU10A-2 - RM 10A-119 | | | 2 | | AI | FI NEW ROOM SENSOR, WIRE TO NEW CONTROLLER | HI TEMP |
| 727 | | HOT WATER VALVE | AHU10A-1,2 (TYP.) | | | | 2 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 728 | | DX COOLING CONTACT | AHU10A-1,2 (TYP.) | | 2 | | | DO | F/I WIRING, PROGRAMMING AND COMMISSIONING FOR DX COIL | CONTROL |
| 729 | | SUPPLY AIR SMOKE DETECTOR | AHU10A-1,2 (TYP.) | 2 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 730 | | RETURN AIR SMOKE DETECTOR | AHU10A-1,2 (TYP.) | 2 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 731 | MAU10A-1 | OUTDOOR AIR DAMPER | AHU10-1 | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|---|--------|----|----|----|--|--|--------------------|
| | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | | | |
| 6 | | | | | | | | | | |
| 732 | MAU10A-1 | FILTER STATUS | AHU10-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 733 | MAU10A-1 | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU10-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 734 | MAU10A-1 | SUPPLY FAN - START / STOP - CT | AHU10-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 735 | EF10A-1, 2, 3, 4 | EXHAUST FAN - START / STOP - CT | EF10A-1, 2, 3, 4 | | 4 | | | DO | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 736 | EF10A-1, 2, 3, 5 | EXHAUST FAN - STATUS - CT | EF10A-1, 2, 3, 5 | 4 | | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 737 | EF10A-1, 2, 3, 4 | EXHAUST FAN DAMPER ACTUATOR | EF10A-1, 2, 3, 4 | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 738 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 739 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 740 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 741 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 742 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 743 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 744 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 745 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 746 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 747 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 748 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 749 | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI | |
| 750 | CP-HT-10A | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 751 | | | | | | | | | | |
| 752 | <u>CP-11-1</u> | AHU11-1 | BLDG. 11 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 753 | | OUTDOOR / MIXED / EXHAUST AIR DAMPER | AHU11-1 | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 754 | | FILTER STATUS | AHU11-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 755 | | SUPPLY AIR TEMPERATURE SENSOR | AHU11-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 756 | | MIXED AIR TEMPERATURE SENSOR | AHU11-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 757 | | RETURN AIR TEMPERATURE SENSOR | AHU11-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 758 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU11-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 759 | | SUPPLY FAN - START / STOP - CT | AHU11-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 760 | | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU11-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 761 | | EXHAUST FAN - START / STOP - CT | AHU11-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 762 | | ROOM TEMP SENSOR | AHU11-1 - RM 11-100 | | | 1 | | AI | FI NEW ROOM SENSOR, WIRE TO NEW CONTROLLER | HI TEMP |
| 763 | | HOT WATER VALVE | AHU11-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 764 | | CHILLED WATER VALVE | AHU11-1 | | 1 | | | DO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | CONTROL |
| 765 | | SUPPLY AIR SMOKE DETECETOR | AHU11-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 766 | | RETURN AIR SMOKE DETECETOR | AHU11-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 767 | | AHU11-1 VFD - START / STOP | AHU11-1 | | 1 | | | DO | | COMMAND |
| 768 | | AHU11-1 VFD - STATUS | AHU11-1 | 1 | | | | DI | | STATUS ON / OFF |
| 769 | | AHU11-1 VFD - SPEED CONTROL | AHU11-1 | | | | 1 | AO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | SPEED OUIPUT |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|---|--------|----|----|----|-----------------------|---|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 6 | | | | | | 1 | | AI | | SPEED READING |
| 770 | | AHU11-1 VFD - SPEED READING | AHU11-1 | | | | | AI | | |
| 771 | | AHU11-1 VFD - BYPASS CONTACT | AHU11-1 | 1 | | | | N/A | | STATUS |
| 772 | | AHU11-1 STATIC PRESSURE SENSOR | AHU11-1 | 1 | | | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 773 | | SUPPLY AIR LOW LIMIT SWITCH | AHU11-1 | 1 | | | | DI | F/I NEW SWITCH - INTERLOCK WITH FAN STARTER | NORMAL / ALARM |
| 774 | | SUPPLY AIR SMOKE DETECETOR | AHU11-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | NOMAL / ALARM |
| 775 | | RETURN AIR SMOKE DETECETOR | AHU11-2 | 2 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | NOMAL / ALARM |
| 776 | FCU11-1,2,3,4 | SUPPLY AIR TEMP | FCU11-1,2,3,4 | | | 4 | | AI | F/I NEW TEMP SENSOR | DEG. F / HI TEMP |
| 777 | FCU11-1,2,3,4 | FREEZ STATS | FCU11-1,2,3,4 | 4 | | | | DI | F/I NEW FREEZSTAT | STATUS |
| 778 | FCU11-1,2,3,4 | FILTER STATUS | FCU11-1,2,3,4 | 4 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE SWITCH | STATUS |
| 779 | FCU11-1,2,3,4 | FAN START / STOP | FCU11-1,2,3,4 | | 4 | | | DO | F/I NEW CT FOR S/S | CONTROL |
| 780 | FCU11-1,2,3,4 | FAN STATUS | FCU11-1,2,3,4 | 4 | | | | DI | F/I NEW CT FOR STATUS | ON / OFF |
| 781 | FCU11-1,2,3,4 | OUTDOOR AIR DAMPER | FCU11-1,2,3,4 | | | | 4 | AO | F/I NEW DAMPER ACTUATOR - EXISTING DAMPER TO REMAIN | DEG. F / HI TEMP |
| 782 | FCU11-1,2,3,4 | HOT WATER VALVE | FCU11-1,2,3,4 | | | | 4 | AO | F/I NEW COOLING VALVE | % OPEN |
| 783 | FCU11-1,2,3,4 | CHILLED WATER VALVE | FCU11-1,2,3,4 | | 4 | | | DO | F/I NEW HEATING VALVE | % OPEN |
| 784 | FCU11-1,2,3,4 | ROOM TEMP SENSOR | FC11-1 - RM 11-100 FC11-2 - RM 11-111 FC11-3 - RM 11-102 FC11-4 - RM 11-105 | | | 4 | | AI | FI NEW ROOM SENSOR, WIRE TO NEW CONTROLLER | HI TEMP |
| 785 | EF11-1,2,3,4 | EXHAUST FAN - START / STOP - CT | EF11-1,2,3,4 | | 4 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 786 | EF11-1,2,3,4 | EXHAUST FAN DAMPER ACTUATOR | EF11-1,2,3,4 | | | | 4 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 787 | EF11-1,2,3,4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF11-1,2,3,4 | 4 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 788 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 789 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 790 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 791 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 792 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 793 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 794 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 795 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 796 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 797 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 798 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 799 | | HOT WATER DIFFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 800 | CP-HT-11 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNCATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 801 | | | | | | | | | | |
| 802 | CP-12-1 (SERVES ROOM 118 - DINING AREA) | AHU12-1 | BLDG. 12 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 803 | | OUTDOOR / MIXED / EXHAUST AIR DAMPER | AHU12-1 | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 804 | | FILTER STATUS | AHU12-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 805 | | SUPPLY AIR TEMPERATURE SENSOR | AHU12-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|--|--|--------|----|----|----|-----------------------|--|---------------------|
| | | | | D | E | F | G | | | |
| 6 | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 806 | | MIXED AIR TEMPERATURE SENSOR | AHU12-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 807 | | RETURN AIR TEMPERATURE SENSOR | AHU12-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 808 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU12-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 809 | | SUPPLY FAN - START / STOP - CT | AHU12-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 810 | | ROOM TEMP SENSOR (LOCATED IN INMATE DINING AREA ROOM 12-118) | AHU12-1 | | | 1 | | AI | FI NEW ROOM SENSOR, WIRE TO NEW CONTROLLER | HI TEMP |
| 811 | | HOT WATER VALVE | AHU12-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 812 | | CHILLED WATER VALVE | AHU12-1 | | | | 1 | AO | FURNISH PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 813 | | SUPPLY AIR SMOKE DETECTOR | AHU12-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | NOMAL / ALARM |
| 814 | | RETURN AIR SMOKE DETECTOR | AHU12-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | NOMAL / ALARM |
| 815 | | AHU12-1 VFD - START / STOP | AHU12-1 | | 1 | | | DO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | COMMAND |
| 816 | | AHU12-1 VFD - STATUS | AHU12-1 | 1 | | | | DI | | STATUS ON / OFF |
| 817 | | AHU12-1 VFD - SPEED CONTROL | AHU12-1 | | | | 1 | AO | | SPEED OUIPUT |
| 818 | | AHU12-1 VFD - SPEED READING | AHU12-1 | | | | 1 | AI | | SPEED READING |
| 819 | | AHU12-1 VFD - BYPASS CONTACT | AHU12-1 | | | | | N/A | | STATUS |
| 820 | | AHU12-1 STATIC PRESSURE SENSOR | AHU12-1 | | | 1 | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 821 | | RETURN DUCT SMOKE DAMPTER | AHU12-1 | | 1 | | | DO | CONNECT TO EXISTING SMK. DPR. | CONTROL |
| 822 | | SUPPLY DUCT SMOKE DAMPTER | AHU12-1 | | 1 | | | DO | CONNECT TO EXISTING SMK. DPR. | CONTROL |
| 823 | | OUTDOOR AIR DAMPER | AHU12-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 824 | | MIXED AIR DAMPER | AHU12-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 825 | | EXHAUST AIR DAMPER | AHU12-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 826 | FCU12-1,2 | FCU-1 SERVES ROOM 115 / FCU-2 SERVES ROOM 105 | | | | | | | | |
| 827 | FCU12-1,2 | SUPPLY AIR TEMP | FCU12-1,2 | | | 2 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 828 | FCU12-1,2 | FREEZ STATS | FCU12-1,2 | 2 | | | | DI | F/I NEW SENSOR | STATUS |
| 829 | FCU12-1,2 | FILTER STATUS | FCU12-1,2 | 2 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE SWITCH | STATUS |
| 830 | FCU12-1,2 | FAN START / STOP | FCU12-1,2 | | 2 | | | DO | F/I NEW CURRENT TRANSDUCER | CONTROL |
| 831 | FCU12-1,2 | FAN STATUS | FCU12-1,2 | 2 | | | | DI | F/I NEW CURRENT TRANSDUCER | ON / OFF |
| 832 | FCU12-1,2 | OUTDOOR AIR DAMPER | FCU12-1,2 | | | | 2 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | DEG. F / HI TEMP |
| 833 | FCU12-1,2 | HOT WATER VALVE | FCU12-1,2 | | | | 2 | AO | F/I NEW COOLING VALVE | % OPEN |
| 834 | FCU12-1,2 | CHILLED WATER VALVE | FCU12-1,2 | | | | 2 | AO | F/I NEW HEATING VALVE | % OPEN |
| 835 | FCU12-1,2 | ROOM TEMP SENSOR | FCU12-1,2 | | | 2 | | AI | FI NEW ROOM SENSOR, WIRE TO NEW CONTROLLER | HI TEMP |
| 836 | EF12-1, 2, 3, 4, 5 | EXHAUST FAN - START / STOP - CT | EF12-1, 2, 3, 4, 5 | | 5 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | |
| 837 | EF12-1, 2, 3, 4, 5 | EXHAUST FAN DAMPER ACTUATOR | EF12-1, 2, 3, 4, 5 | | | | 5 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 838 | EF12-1, 2, 3, 4, 5 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF12-1, 2, 3, 4, 5 | 5 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 839 | MAU12-1 | OUTDOOR AIR DAMPER | MAU12-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 840 | MAU12-1 | MIXED AIR DAMPER | MAU12-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 841 | MAU12-1 | FILTER STATUS | MAU12-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 842 | MAU12-1 | MIXED AIR TEMPERATURE SENSOR | MAU12-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 843 | MAU12-1 | MAU7-1 SMOKE DETECTOR | MAU12-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 844 | MAU12-1 | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | MAU12-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 845 | MAU12-1 | SUPPLY FAN - START / STOP - CT | MAU12-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | START / STOP |
| 846 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 847 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 848 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 849 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 850 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|---|--------|----|----|----|-----------------------|--|---------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 851 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 852 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 853 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 854 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 855 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 856 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 857 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 858 | CP-HT-12 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 859 | | | | | | | | | | |
| 860 | CP-13-1 | AHU13-1 | BLDG. 13 MECHANICAL MEZZ REFER TO DRAWINGS M750 THRU M769 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 861 | | OUTDOOR / MIXED / EXHAUST AIR DAMPER | AHU13-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 862 | | FILTER STATUS | AHU13-1 | 1 | | | | DI | F/I NEW DIFFERENTIAL PRESSURE TRANSMITTER | SP - CHNG FLT. |
| 863 | | SUPPLY AIR TEMPERATURE SENSOR | AHU13-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 864 | | MIXED AIR TEMPERATURE SENSOR | AHU13-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 865 | | RETURN AIR TEMPERATURE SENSOR | AHU13-1 | | | 1 | | AI | F/I NEW SENSOR | DEG. F / HI TEMP |
| 866 | | SUPPLY FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU13-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 867 | | SUPPLY FAN - START / STOP - CT | AHU13-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 868 | EF13-1 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | AHU13-1 | 1 | | | | DI | F/I NEW SWITCH | STATUS - ON/OFF |
| 869 | EF13-1 | EXHAUST FAN - START / STOP - CT | AHU13-1 | | 1 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 870 | EF13-1 | EXHAUST FAN DAMPER ACTUATOR | AHU13-1 | | | | 1 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 871 | | ROOM TEMP SENSOR | AHU13-1 | | | 1 | | AI | FI NEW ROOM SENSOR, WIRE TO NEW CONTROLLER | DEG. F / HI TEMP |
| 872 | | HOT WATER VALVE | AHU13-1 | | | | 1 | AO | FURNISH NEW PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 873 | | CHILLED WATER VALVE | AHU13-1 | | 1 | | | DO | FURNISH NEW PICV - INSTALLED BY MECHANICAL CONT. | % OPEN |
| 874 | | SUPPLY AIR SMOKE DETECTOR | AHU13-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 875 | | RETURN AIR SMOKE DETECTOR | AHU13-1 | 1 | | | | DI | REUSE EXISTING SMK DET. - INTERLOCK WITH FAS | STATUS |
| 876 | | AHU13-1 VFD - START / STOP | AHU13-1 | | 1 | | | DO | | COMMAND |
| 877 | | AHU13-1 VFD - STATUS | AHU13-1 | 1 | | | | DI | | STATUS ON / OFF |
| 878 | | AHU13-1 VFD - SPEED CONTROL | AHU13-1 | | | | 1 | AO | WIRE TO EXISTING VFD, SET VFD PARAMETERS AS REQUIRED. | SPEED OUIPUT |
| 879 | | AHU13-1 VFD - SPEED READING | AHU13-1 | | | 1 | | AI | | SPEED READING |
| 880 | | AHU13-1 VFD - BYPASS CONTACT | AHU13-1 | | 1 | | | N/A | | STATUS |
| 881 | | AHU13-1 STATIC PRESSURE SENSOR | AHU13-1 | | | 1 | | AI | INSTALL NEW SPT 2/3 DOWN LONGEST MAIN DUCT. | SP-IN. |
| 882 | | SUPPLY AIR LOW LIMIT SWITCH | AHU13-1 | 1 | | | | DI | F/I NEW SWITCH - INTERLOCK WITH FAN STARTER | NORMAL / ALARM |
| 883 | | TU13-1 | RM-13-108 | | | | | | | |
| 884 | | TU13-2 | RM-13-109 | | | | | | | |
| 885 | | TU13-3 | RM-13-116 | | | | | | | |
| 886 | | TU13-4 | RM-13-145 | | | | | | | |
| 887 | | TU13-5 | RM-13-144 | | | | | | | |
| 888 | | TU13-6 | RM-13-147 | | | | | | | |
| 889 | | TU13-7 | RM-13-148 | | | | | | | |
| 890 | | TU13-8 | RM-13-121 | | | | | | | |
| 891 | | TU13-9 | RM-13-122 | | | | | | | |
| 892 | | TU13-10 | RM-13-124 | | | | | | | |
| 893 | | TU13-11 | RM-13-101W | | | | | | | |
| 894 | | TU13-12 | RM-13-101E | | | | | | TU-1 THROUGH TU-16: REPLACE EXISTING CONTROLLER WITH NEW TERMINAL UNIT CONTROLLER. EXISTING REHEAT VALVES SHALL REMAIN AND BE REUSED. F/I WIRING TO EXISTING VALVE. REPLACE EXISTING WALL SENSOR AS INDICATED IN NOTES SECTION. EXTEND NEW CONTROLLER COMMUNICATION SUBNETWORK CONNECTED TO NEAREST MASTER (IP LEVEL) CONTROLLER. | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|---|--|--------|----|----|----|-----------------------|--|---------------------|
| | | | | D | E | F | G | | | |
| 6 | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 895 | | TU13-13 | RM-13-102 | | | | | | | |
| 896 | | TU13-14 | RM-13-141 | | | | | | | |
| 897 | | TU13-15 | RM-13-137 | | | | | | | |
| 898 | | TU13-16 | RM-13-135 | | | | | | | |
| 899 | CV13-1, 2, 3, 4 | CONVECTOR | CV13-1, 2, 3, 4 | | | | | STAND ALONE | F/I LOCAL THERMOSTAT IN SAME LOCATION AS EXISTING. | N/A - STAND ALONE |
| 900 | EF13-2.3.4 | EXHAUST FAN STATUS - DIFFERENTIAL PRESSURE SWITCH (TYP.) | EF13-2.3.4 | 3 | | | | | F/I NEW SWITCH | STATUS - ON/OFF |
| 901 | EF13-2.3.4 | EXHAUST FAN - START / STOP - CT | EF13-2.3.4 | | 3 | | | DI | F/I CURRENT TRANSDUCER - HAWKEYE | CONTROL |
| 902 | EF13-2.3.4 | EXHAUST FAN DAMPER ACTUATOR | EF13-2.3.4 | | | | 3 | AO | F/I NEW ELECTRONIC DAMPER ACTUATOR / EXISTING DAMPER REMAINS | % OPEN |
| 903 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 904 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 905 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 906 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 907 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 908 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 909 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 910 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 911 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 912 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 913 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 914 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 915 | CP-HT-13 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 916 | | | | | | | | | | |
| 917 | <u>CP-22-1</u> | BUILDING 22 HOT WATER LOOP | BLDG. 22 MECHANICAL MEZZ REFER TO DRAWING M736 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 918 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 919 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 920 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 921 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 922 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 923 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 924 | | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 925 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |

| 5 | A | B | C | D | E | F | G | H | I | J |
|-----|--|---|---|--------|----|----|---|-------------------------|---|---------------------|
| | 6 | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | POINTS | | | | PROTOCOL/ POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| DI | | | | DO | AI | AO | | | | |
| 926 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 927 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 928 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 929 | | HOT WATER DIFFRENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 930 | CP-HT-23 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNCATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 931 | | | | | | | | | | |
| 932 | CP-23-1 | BUILDING 22 HOT WATER LOOP | BLDG. 23 MECHANICAL MEZZ REFER TO DRAWING M737 FOR PANEL AND EQUIPMENT LOCATION AS WELL AS CABLE ROUTING | | | | | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 933 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 934 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 935 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 936 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 937 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 938 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 939 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 940 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 941 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 942 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 943 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 944 | | HOT WATER DIFFRENTIAL PRESSURE | HWDP | | | 1 | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 945 | CP-HT-25 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNCATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 946 | | | | | | | | | | |

| 5 | A | B | C | POINTS | | | | H | I | J |
|-----|--|--|---|--------|----|----|----|--------|---|-------------------------|
| | PANEL / SYSTEM | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | | | |
| 6 | | | | | | | | | | |
| 947 | <u>CP-10-0</u> <u>CHILLER / CONDENSER WATER</u> <u>SYSTEMS</u> | CENTRAL MECHANICAL PLANT - CHILLER SYSTEMS BALANCE OF PLANT (BOP) | BLDG. 10 MECHANICAL ROOM REFER TO DRAWINGS M750 THRU M769 THROUGH M769 FOR PANEL AND EQUIPMENT LOCATIONS AS WELL AS CABLE ROUTING. REFER TO DRAWING M301, M204, M907, M202, M904, M302 AND M206 FOR ADDITIONAL PLANT DETAIL. | AI | DO | DI | AO | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. CONTRACTOR IS TO COORDINATE AND VERIFY CONDUIT RUNS PRIOR TO INSTALLATION. | PANEL OFFLINE |
| 948 | | CHILLER CONTROL PANEL (INTEGRATION - TYP.3) | | | | | | BACnet | INTEGRATE TO EQUIPMENT PROVIDED CONTROLLER | CONTROLLER OFFLINE |
| 949 | | CHILLER 1, 2 AND 3 CHILLED WATER SUPPLY TEMP | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CHWS-T / OUT OF RANGE |
| 950 | | CHILLER 1, 2 AND 3 CHILLED WATER RETURN TEMP | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CHWR-T / OUT OF RANGE |
| 951 | | CHILLER 1, 2 AND 3 CHILLED WATER BTU (SUPPLY WATER FLOW) | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CHWR-BTU / OUT OF RANGE |
| 952 | | CHILLER 1, 2 AND 3 CHILLED WATER SUPPLY PRESSURE | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | BTU |
| 953 | | CHILLER 1, 2 AND 3 CONDENSER WATER SUPPLY TEMP | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CWS-T / OUT OF RANGE |
| 954 | | CHILLER 1, 2 AND 3 CONDENSER WATER RETURN TEMP | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CWS-R / OUT OF RANGE |
| 955 | | CHILLER 1, 2 AND 3 CONDENSER WATER BTU (RETURN WATER FLOW) | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CWR-BTU / OUT OF RANGE |
| 956 | | CHILLER 1, 2 AND 3 CONDENSER WATER RETURN PRESSURE | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | CWS-T / OUT OF RANGE |
| 957 | | CHILLER 1, 2 AND 3 SUPPLY VALVE (MOV) CONTROL | | | | | 3 | DO | FURNISH ONLY, WIRE PROGRAMING AND CX., INSTALLED BY MECHANICAL | CHWS-VLV / FAILURE |
| 958 | | CHILLER 1, 2 AND 3 SUPPLY VALVE (MOV) STATUS | | 3 | | | | DI | WIRE TO VALVE PROVIDED CONTACT AND PROGRAM POINT INTO BMS / OWS | OPEN/CLOSED |
| 959 | | CHILLER 1, 2 AND 3 RETURN VALVE (MOV) CONTROL | | | | | 3 | DO | FURNISH ONLY, WIRE PROGRAMING AND CX., INSTALLED BY MECHANICAL | CHWR-VLV / FAILURE |
| 960 | | CHILLER 1, 2 AND 3 RETURN VALVE (MOV) STATUS | | 3 | | | | DI | WIRE TO VALVE PROVIDED CONTACT AND PROGRAM POINT INTO BMS / OWS | OPEN/CLOSED |
| 961 | | COMMON CHILLED WATER SUPPLY TEMP. | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | LO TEMP |
| 962 | | COMMON CHILLED WATER RETURN TEMP. | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | LO TEMP |
| 963 | | COMMON CHILLED WATER BTU (SUPPLY WATER FLOW) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | BTU |
| 964 | | COMMON CHILLED WATER SUPPLY PRESSURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | HI PRESS. |
| 965 | | COMMON CHILLED WATER RETURN SUPPLY PRESSURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | HI PRESS. |
| 966 | | COMMON CHILLED WATER DIFFERENTIAL PRESSURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | OUT OF RANGE |
| 967 | | COMMON CONDENSER WATER SUPPLY TEMP. | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | TEMP / LO TEMP |
| 968 | | COMMON CONDENSER WATER RETURN TEMP. | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | TEMP / LO TEMP |
| 969 | | COMMON CONDENSER WATER BTU (RETURN WATER FLOW) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY MECHANICAL CONTRACTOR | BTU |
| 970 | | SAND FILTER COMMON ALARM | | 1 | | | | AI | WIRE TO PANEL AND PROGRAM INTO BMS. DRY CONTACT F/I BY OTHERS | NORMAL / ALARM |
| 971 | | CONDENSER WATER MAKE UP FLOW TRANSMITTER | | | | 1 | | AI | FURNISH FLOW TRANSMITTER, WIRE AND COMMISSION. | GPM / LOW FLOW |
| 972 | | CHILLED WATER EXPANSION TANK PRESSURE TRANSMITTER | | | | 1 | | AI | WIRE TO SENSOR AND PROGRAM INTO BMS. SENSOR F/I BY OTHERS | HI PRESS. |
| 973 | | CHILLED WATER EXPANSION TANK FLOW TRANSMITTER | | | | 1 | | AI | FURNISH FLOW TRANSMITTER, WIRE AND COMMISSION. | GPM / LOW FLOW |

| 5 | A | B | C | D | E | F | G | H | I | J |
|------|---------------------------------|---|---|----|----|----|----|-----------------------|--|--------------------------|
| | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | PROTOCOL / POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| 974 | | CONDENSER WATER SIDE STREAM FILTER COMMON ALARM | | 1 | | | | DI | WIRE TO PANEL AND PROGRAM INTO BMS. DRY CONTACT F/I BY OTHERS | ALARM |
| 975 | | OUTDOOR AIR TEMP. | | 1 | | | | AI | F/I OUTDOOR AIR AND HUMIDITY SENSOR. VALUE TO BE GLOBAL DATA POINT. | DEG, F / HI TEMP |
| 976 | | OUTDOOR AIR HUM. | | 1 | | | | AI | | % HUM, / HI HUMIDY |
| 977 | | | | | | | | | | |
| 978 | CP-10-2 COOLING TOWER SYSTEM | CENTRAL MECHANICAL PLANT - COOLING TOWER SYSTEMS | BLDG. 10 MECHANICAL ROOM | AI | AO | DI | DO | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 979 | | COOLING TOWER 1, 2 AND 3 CW RETURN SUPPLY VALVE (MOV) CONTROL | | | | | 3 | DO | FURNISH ONLY, WIRE PROGRAMING AND CX., INSTALLED BY MECHANICA | OPEN/CLOSED |
| 980 | | COOLING TOWER 1, 2 AND 3 SUPPLY VALVE (MOV) STATUS | | | | 3 | | DI | WIRE TO VALVE PROVIDED CONTACT | OPEN/CLOSED |
| 981 | | COOLING TOWER 1, 2 AND 3 VIBRATION SENSOR | | 3 | | | | DI | WIRE TO VIBRATION SENSOR AND PROGRAM INTO BMS. SENSOR IS F/I BY CT PROVIDER | VIBRATION HI LIMIT |
| 982 | | COOLING TOWER 1, 2 AND 3 CONDENSER WATER TRANSMITTERS | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | TEMP / LO TEMP |
| 983 | | COOLING TOWER 1, 2 AND 3 CONDENSER WATER TRANSMITTERS | | | | | 3 | AO | FURNISH ONLY, WIRE PROGRAMING AND CX., INSTALLED BY MECHANICA | POSITION / ALARM |
| 984 | | | | | | | | | | |
| 985 | CP-10-3 BOILER SYSTEMS | CENTRAL MECHANICAL PLANT - BOILER SYSTEMS BALANCE OF PLANT (BOP) | BLDG. 10 MECHANICAL ROOM REFER TO DRAWING M763 FOR PANEL AND EQUIPMENT LOCATIONS AS WELL AS CABLE ROUTING. REFER TO DRAWING M301, M204, M907, M202, M904, M302 AND M206 FOR ADDITIONAL DETAIL. | AI | AO | DI | DO | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 986 | | BOILER MASTER PANEL (INTEGRATION) | | | | | | BACnet | | PANEL OFFLINE ALM. |
| 987 | | BOILER 1, 2 AND 3 SUPPLY TEMPERATURE | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HWS-T / HI TEMP ALM. |
| 988 | | BOILER 1, 2 AND 3 RETURN TEMPERATURE | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HWR-T / HI TEMP ALM. |
| 989 | | BOILER 1, 2 AND 3 SUPPLY PRESSURE | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HWS-P / HI PRESS ALM. |
| 990 | | BOILER 1, 2 AND 3 RETURN PRESSURE | | 3 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HWR-P / HI PRESS ALM. |
| 991 | | BOILER 1, 2 AND 3 HOT WATER RETURN FLOW (GPM / BTU) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-BTU / LOW/NO FLOWALM. |
| 992 | | BOILER 1, 2 AND 3 RETURN VALVE (MOV) CONTROL | | | | | 3 | DO | FURNISH ONLY, WIRE PROGRAMING AND CX., INSTALLED BY MECHANICA | |
| 993 | | BOILER 1, 2 AND 3 RETURN VALVE (MOV) STATUS | | | | 3 | | DI | WIRE TO VALVE PROVIDED CONTACT | OPEN/CLOSED |
| 994 | | COMMON HOT WATER SUPPLY TEMPERATURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-T / HI TEMP ALM. |
| 995 | | COMMON HOT WATER SUPPLY PRESSURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-P / HI PRESS ALM. |
| 996 | | COMMON HOT WATER SUPPLY FLOW (GPM / BTU) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-BTU / LOW/NO FLOWALM. |
| 997 | | COMMON HOT WATER RETURN, TEMPERATURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-T / HI TEMP ALM. |
| 998 | | COMMON HOT WATER RETURN PRESSURE | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-P / HI PRESS ALM. |
| 999 | | COMMON HOT WATER DIFFERENTIAL PRESSURE (TRANSMITTER) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | HW-DP / OUT OF RANGE |
| 1000 | | HOT WATER EXPANSION TANK PRESSURE TRANSMITTER | | | | 1 | | AI | WIRE TO SENSOR AND PROGRAM INTO BMS. SENSOR F/I BY OTHERS | HI PRESS. |
| 1001 | | HOT WATER EXPANSION TANK FLOW TRANSMITTER | | | | 1 | | AI | FURNISH FLOW TRANSMITER, INSTALLED BY MECH, | GPM / LOW FLOW |
| 1002 | | MAIN GAS SUPPLY FLOW (CFH) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | CFH / LOW - HI - FLOW |

| 5 | A | B | C | POINTS | | | | H | I | J |
|------|--|---|--|--------|----|----|----|--------|--|-----------------------|
| | <u>PANEL / SYSTEM</u> | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | DI | DO | AI | AO | | | |
| 1003 | | MAIN GAS SUPPLY PRESSURE (PSI) | | 1 | | | | AI | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI / LOW-HI PRESSURE |
| 1004 | | | | | | | | | | |
| 1005 | <u>CP-10-4 LOOP CONTROLS</u> | CENTRAL MECHANICAL PLANT - MAIN BLDG. CHILLED AND HOT WATER MEDIUM WATER LOOP | BLDG. 10 MECHANICAL ROOM REFER TO DRAWING M763 FOR PANEL AND EQUIPMENT LOCATIONS AS WELL AS CABLE ROUTING. REFER TO DRAWING M301, M204, M907, M202, M904, M302 AND M206 FOR ADDITIONAL DETAIL. | AI | AO | DI | DO | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 1006 | MAIN BUILDING MER CHILLED WATER SERVICE | CHILLED WATER SUPPLY TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 1007 | | CHILLED WATER RETURN TEMPERATURE | MAIN BLDG. MER CHW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 1008 | | CHILLED WATER RETURN FLOW | MAIN BLDG. MER CHW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 1009 | | CHILLED WATER SUPPLY PRESSURE | CHWSP | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 1010 | | CHILLED WATER RETURN PRESSURE | CHWRP | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 1011 | | CHILLED WATER DIFFERENTIAL PRESSURE | CHWDP | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 1012 | MAIN BUILDING MER MEDIUM TEMPERATURE HOT WATER SERVICE | HOT WATER SUPPLY TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 1013 | | HOT WATER RETURN TEMPERATURE | MAIN BLDG. MER HW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | DEG. F / BTU |
| 1014 | | HOT WATER RETURN FLOW | MAIN BLDG. MER HW BTU | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | GPM / BTU |
| 1015 | | HOT WATER SUPPLY PRESSURE | HWSP | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 1016 | | HOT WATER RETURN PRESSURE | HWRP | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 1017 | | HOT WATER DIFFERENTIAL PRESSURE | HWDP | | | 1 | | | F/I NEW SENSOR, WIRE, PROGRAMMING AND Cx -WELDOLET BY OTHERS | PSI |
| 1018 | CP-HT-10 | HEAT TRACE PANEL (PROVIDED BY OTHERS - INTEGRATED BY THIS CONTRACTOR) | MAIN BLDG. MER | | | | | BACnet | PROVIDE COMMUNICATION WIRE, INTEGRATE BACNET | NORMAL / ALARM |
| 1019 | | | | | | | | | | |
| 1020 | <u>CP-10-5 VFDS</u> | CENTRAL MECHANICAL PLANT - VARIABLE FREQUENCY DRIVES | BLDG. 10 MECHANICAL ROOM REFER TO DRAWING M763 FOR PANEL AND EQUIPMENT LOCATIONS AS WELL AS CABLE ROUTING. REFER TO DRAWING M301, M204, M907, M202, M904, M302 AND M206 FOR ADDITIONAL DETAIL. | AI | AO | DI | DO | BACnet | FURNISH AND INTALL (F/I) A NEW CONTROL PANEL TO CONNECT POINTS AND DEVICES AS LISTED HEREIN. | CONTROLLER OFFLINE |
| 1021 | TOTAL OF 9 VFDS 3 VFDS - CHILLED WATER PUMP 3 VFDS CT FANS 3 VFDS HOT WATER PUMPS | VARIABLE FREQUENCY DRIVE POINTS (3-CHW-VFD, 3 CTfan VFD, 3-HW VFD) | | | | | | BACNET | INTEGRATE NEW VFS INTO BMS, PROGRAM FOR A MINIMUM OF 15 INT. POINTS | |
| 1022 | | START/STOP | | | 9 | | | AO | WIRE TO TERMINAL FOR POINT ON NEW VFD, PROGRAM, COMMISSION AND PROVIDE GRAPHICS | |
| 1023 | | STATUS | | 9 | | | | AI | WIRE TO TERMINAL FOR POINT ON NEW VFD, PROGRAM, COMMISSION AND PROVIDE GRAPHICS | |
| 1024 | | VFD SPEED OUTPUT | | | | | 9 | DO | WIRE TO TERMINAL FOR POINT ON NEW VFD, PROGRAM, COMMISSION AND PROVIDE GRAPHICS | |

| 5 | A | B | C | D | E | F | G | H | I | J |
|------|--------------------|--|--|--------|----|----|---|-------------------------|---|---------------------|
| | 6 | SYSTEM / POINT NAME | DEVICE / EQUIP. LOCATION / AREA SERVED | POINTS | | | | PROTOCOL/ POINT TYPE | SCOPE | OWS DISPLAY / ALARM |
| DI | | | | DO | AI | AO | | | | |
| 1025 | | VFD SPEED FEEDBACK | | | | 9 | | DI | WIRE TO TERMINAL FOR POINT ON NEW VFD, PROGRAM, COMMISSION AND PROVIDE GRAPHICS | |
| 1026 | | BYPASS INDICATION | | | | | 9 | DI | WIRE TO TERMINAL FOR POINT ON NEW VFD, PROGRAM, COMMISSION AND PROVIDE GRAPHICS | |
| 1027 | | | | | | | | | | |
| 1028 | INTEGRATED SYSTEMS | GAS LEAK DETECTION | | | | | | | | |
| 1029 | | REFRIGERANT LEAK DETECTION PANEL (INTEGRATION) | | | | | | BACnet | INTEGRATE TO 3RD PARTY SYSTEM | |
| 1030 | | FUEL OIL PUMP SKID (INTEGRATION) | | | | | | BACnet | INTEGRATE TO 3RD PARTY SYSTEM | |
| 1031 | | REMOTE DIALER | | | | | | BACnet | INTEGRATE TO 3RD PARTY SYSTEM | |
| 1032 | | CHILLED AND HOT WATER VFDS | | | | | | BACnet | INTEGRATE TO 3RD PARTY SYSTEM | |
| 1033 | | VARIABLE FREQUENCY DRIVE (TYPICAL) | | | | | | BACnet | INTEGRATE TO EXISTING AND NEW VFDS | |
| 1034 | | START/STOP | | | 1 | | | DO | | |
| 1035 | | STATUS | | 1 | | | | DI | EXTEND POINT WIRE AND PROVIDE PROGRAMMING, AND COMMISSIONING AS SPECIFIED. | |
| 1036 | | VFD SPEED OUTPUT | | | | 1 | | AO | | |
| 1037 | | VFD SPEED FEEDBACK | | | 1 | | | AI | | |

The following Sequences are provided for reference only. This contractor shall verify that all components, programming, devices and commissioning required to achieve these sequences are included in their scope of work. These sequences are based on the existing equipment controls and operations. This contractor shall ensure proper operation using these sequences during commissioning.

BUILDINGS - SEQUENCE OF OPERATION

BUILDING 1

AHU1-1 (AHU1-2, AHU1-3, AHU1-4, and AHU1-5 Typical) EF1-X (Typical)

The occupied and unoccupied mode of operation is manually selected from the BMS.

Normal operation is for the air handling unit to operate 24 hours a day, 7 days a week in the occupied mode.

During the occupied mode, the supply fan operates continuously and the intake air damper opens to its minimum position, as field verified.

During the unoccupied mode both fan remain off and the intake air damper closes.

Normal Operation:

Each zone temperature sensor will modulate its respective zone mixing dampers to maintain the zone temperature setpoint (adj.), by mixing air from the hot and cold decks. Some zones have space temperature sensor and some zones have return air temperature sensor, as shown in the Points Schedule.

The hot deck temperature setpoint will be reset by the zone sensor with the greatest demand for heating the hot deck temp sensor will modulate the hot water valve to maintain the required hot deck temperature.

The cold deck temperature setpoint will be reset by the zone sensor with the greatest demand for cooling. The cold deck temp sensor will modulate the intake air damper and the mixing air damper in sequence with the chilled water valve to maintain the required cold deck temperature.

Whenever the supply fan is operating the intake air damper opens to its minimum position, as field verified. On an initial call for cooling from the cold deck temp sensor, the intake air damper will be modulated beyond its minimum position to maintain cold deck setpoint.

Once the intake air damper is fully open and there is a continued call for cooling from the cold deck temp sensor, the chilled water valve will be modulated open to maintain the cold deck setpoint.

The position of the intake air damper is subject to the mixed air low limit temperature setpoint as sensed by the mixed air temp sensor.

Exhaust fan EF1-X will remain off and the exhaust air damper will remain closed until the intake air damper is fully open, at which time EF1-X will start and the exhaust air damper will open fully. When the intake air damper is not fully open, EF1-X will remain off and the exhaust air damper will remain closed.

Modulation of the intake air damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing dampers are allowed to modulate. When the outside temperature is above 55 degrees, the enthalpy content of the outside is compared to the enthalpy content of the return air. The intake air damper will be returned to and remain at a position to admit only its minimum amount of outside air for ventilation purpose and EF3-1 will stop and the exhaust air damper will close.

An outside air temperature switchover setpoint is provided. This set point is manually adjustable from the BMS. When the outside air temperature is above this setpoint, the hot water valve is not allowed to open. When the outside air temperature is below this setpoint, the chilled water valve is not allowed to open. Therefore, the unit cannot operate with mechanical heating and mechanical cooling at the same time. This setpoint will be set at 60 degree(adjustable).

Upon sensing an air temperature of less than 35 degree entering the cooling coil, the freezestat will stop the supply fan, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The BMS need to be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply fan and all exhaust fans connected to this system upon activation by the building fire alarm system.

TOILET EXHAUST FANS EF1-6A, 6B, 6C AND EF1-7

The toilet exhaust fans operate continuously. When the exhaust fan starts, it's respective exhaust damper opens. The fans may be started and stopped from the BMS. Fan status will be monitored by the BMS and an alarm will be indicated if the fan stops.

MEZZ. EXHAUST FANS EF1-9 & 10

When the relative humidity exceeds 60%(adjustable), as sensed by exhaust duct humidity sensor, the exhaust fan will be started. When the exhaust fan starts, the exhaust damper and outside air intake damper will open.

BUILDING 2

AHU2-1 (AHU2-2, AHU2-3, AHU2-4, and AHU2-5 Typical) EF2-X (Typical)

The occupied and unoccupied mode of operation is manually selected from the BMS.

Normal operation is for the air handling unit to operate 24 hours a day, 7 days a week in the occupied mode.

During the occupied mode, the supply fan operates continuously and the intake air damper opens to its minimum position, as field verified.

During the unoccupied mode both fan remain off and the intake air damper closes.

Normal Operation:

Each zone temperature sensor will modulate its respective zone mixing dampers to maintain the zone temperature setpoint (adj.), by mixing air from the hot and cold decks.

Some zones have space temperature sensor and some zones have return air temperature sensor, as shown in the points schedule.

The hot deck temperature setpoint will be reset by the zone sensor with the greatest demand for heating. The hot deck temp sensor will modulate the hot water valve to maintain the required hot deck temperature.

The cold deck temperature setpoint will be reset by the zone sensor with the greatest demand for cooling. The cold deck temp sensor will modulate the intake air damper in sequence with the chilled water valve to maintain the required cold deck temperature.

Whenever the supply fan is operating the intake air damper opens to its minimum position, as field verified. On an initial call for cooling from the cold deck temp sensor, the intake air damper will be modulated beyond its minimum position to maintain the cold deck setpoint.

Once the intake air damper is fully open and there is a continued call for cooling from the cold deck temp sensor, the chilled water valve will be modulated open to maintain the cold deck setpoint.

The position of the intake air damper is subject to the mixed air low limit temperature setpoint as sensed by the mixed air temp sensor.

Exhaust fan EF2-X will remain off and the exhaust damper will remain closed until the intake air damper is fully open, at which time EF2-1 will start and the exhaust air damper will open fully. When the intake air damper is not fully open, EF2-X will remain off and the exhaust air damper will remain closed.

Modulation of the intake air damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing dampers are allowed to modulate. When the outside temperature above 55 degrees, the enthalpy content of the outside is compared to the enthalpy content of the return air. When the enthalpy content of the outside air exceeds the enthalpy content of the return air, the intake air damper will be returned to and remain at a position to admit only a minimum amount of outside air for ventilation purpose and EF3-X will stop and the exhaust air damper will close.

An outside air temperature switchover setpoint is provided. This setpoint is manually adjustable from the BMS. When the outside air temperature is above this setpoint, the hot water valve is not allowed to open. When the outside air temperature is below this setpoint, the chilled water valve is not allowed to open. Therefore, the unit cannot operate with mechanical heating and mechanical cooling at the same time. This setpoint will be set at 60 degree(adjustable).

Upon sensing an air temperature of less than 35 degree entering the cooling coil, the freezestat will stop the supply fan, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The BMS need to be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply fan and EF2-X upon activation by the building fire alarm system.

TOILET EXHAUST FANS EF2-6A, 6B, 6C and EF2-7

The toilet exhaust fans operate continuously. When the exhaust fan starts, it's respective exhaust damper opens. The fans may be started and stopped from the BMS. Fan status will be monitored by the BMS and an alarm will be indicated if the fan stops.

MEZZ. EXHAUST FANS EF2-9 & EF2-10

When the relative humidity exceeds 60%(adjustable), as sensed by exhaust duct humidity sensor the exhaust fan will be started. When the exhaust fan starts, the exhaust damper and outside air intake damper will open.

BUILDING 3

AHU3-1 (AHU3-2, AHU3-3, AHU3-4, AHU3-5 and AHU3-6 Typical) EF3-X (Typical)

The occupied and unoccupied mode of operation is manually selected from the BMS.

Normal operation is for the air handling unit to operate 24 hours a day, 7 days a week in the occupied mode.

During the occupied mode, the supply fan operates continuously and the intake air damper opens to its minimum position as field verified.

During the unoccupied mode both fans remain off and the intake air damper closes

Each zone temperature sensor will modulate its respective zone mixing dampers to maintain the zone temperature setpoint, by mixing air from the hot and cold decks.

The hot deck temperature setpoint will be reset by the zone sensor with the greatest demand for heating. the hot deck temp sensor will modulate the hot water valve to maintain the required hot deck temperature.

The cold deck temperature setpoint will be reset by the zone sensor with the greatest demand for cooling. the cold deck temp sensor will modulate the intake air damper and the mixing air damper in sequence with the chilled water valve to maintain the required cold deck temperature.

Whenever the supply fan is operating the intake air damper opens to a minimum position.

On an initial call for cooling from the cold deck temp sensor, the intake air damper will be modulated beyond its minimum position to maintain the cold deck setpoint.

Once the intake air damper is fully open and there is a continued call for cooling from the cold deck temp sensor, the chilled water valve will be modulated open to maintain the cold deck setpoint.

The position of the intake air damper is subject to a mixed air low limit temperature as sensed by the mixed air temp sensor.

Exhaust fan EF3-X will remain off and the exhaust damper will remain closed until the inside air damper is fully open, at which time EF3-X will start and the exhaust air damper will open fully. When the intake air damper is not fully open, EF3-X will remain off and the exhaust air damper will remain closed.

Modulation of the intake air damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing dampers are allowed to modulate. When the outside temperature above 55 degrees, the enthalpy content of the outside is compared to the enthalpy content of the return air. When the enthalpy content of the outside air exceeds the enthalpy content of the returned air, the intake air damper will be returned to and remain at a position to admit only its minimum amount of outside air for ventilation purpose and EF3-X will stop and the exhaust air damper will close.

An outside air temperature switchover setpoint is provided. This set point is manually adjustable from the BMS. When the outside air temperature is above this setpoint, hot water valve is not allowed to open. When the outside air temperature is below this setpoint, the chilled water valve is not allowed to open. Therefore, the unit cannot operate with mechanical heating and mechanical cooling at the same time. This setpoint will be set at 60 degree(adjustable).

Upon sensing an air temperature of less than 35 degree entering the cooling coil the freeze stat will stop the supply fan, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The BMS need to be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply fan and EF3-1 upon activation by the building fire alarm system.

EXHAUST FAN EF3-5

Exhaust fan EF3-5 is interlocked with both AHU3-5 and AHU3-6. Before EF3-5 will start, both AHU-5 and AHU-6 must be operating on 100% outside air. When EF3-5 start, the exhaust dampers for AHU3-6 will open.

SMOKE PURGE CYCLE (AHU3-4 ONLY)

AHU3-4 is provided with a smoke purge cycle. The smoke purge system consists of AHU3-4 supply fan, EF3-4 exhaust fan and smoke dampers SD1 thru SD11.

The smoke purge area is divided into three smoke zones;

Smoke Zone 1 = Upper level lounge 3U-E03

Smoke Zone 2 = Lower level lounge 3L-E03

Smoke Zone 3 = Inmate room area 'E'

Relays are activated by the building fire alarm system to indicate which of the three smoke zone are in alarm.

If no smoke zones are in alarm, the air handling unit will operate normally and all smoke damper will be open. Note, SD3 & 4 will open to their normal operation position of 10%(adjustable).

1. When smoke zone 1, or smoke zones 1 and 3, are activated the following will occur;
 - a) AHU3-4 supply fan will start regardless of the position of the 'HAND-OFF-AUTO' switch on the fan's magnetic starter and regardless of the status of low temperature thermostat and regardless of the status of the duct smoke detectors.
 - b) EF3-4 exhaust fan will start regardless of the position of the 'HAND-OFF-AUTO' switch on the fan's magnetic starter and regardless of the status of the duct smoke detectors.
 - c) The outside air damper and the exhaust air damper will fully open and the return air damper will fully close.

- d) Smoke damper positions will be as follows;
 - SD #1 = Open
 - SD #2 = Closed
 - SD #3 = Closed
 - SD #4 = Open
 - SD #5 = Closed
 - SD #6 = Closed
 - SD #7 = Closed
 - SD #8 = Open
 - SD #9 = 20% Open
 - SD #10 = Closed
 - SD #11 = Closed
 - e) The hot deck hot water valve will be commanded fully open.
2. When smoke zone 2, or smoke zones 2 and 3, are activated the following will occur;
- a) AHU3-4 supply fan will start regardless of the position of the 'HAND-OFF-AUTO' switch on the fan's magnetic starter and regardless of the status of low temperature thermostat and regardless of the status of the duct smoke detectors.
 - b) EF3-4 exhaust fan will start regardless of the position of the 'HAND-OFF-AUTO' switch on the fan's magnetic starter and regardless of the status of the duct smoke detectors.
 - c) The outside air damper and the exhaust air damper will fully open and the return air damper will fully close.
 - d) Smoke damper positions will be as follows;
 - SD #1 = Open
 - SD #2 = Closed
 - SD #3 = Closed
 - SD #4 = Open
 - SD #5 = Closed
 - SD #6 = Closed
 - SD #7 = Closed
 - SD #8 = Open
 - SD #9 = 20% Open
 - SD #10 = Closed
 - SD #11 = Closed
 - e) The hot deck hot water valve will be commanded fully open.
3. When smoke zone 3, is activated the following will occur;
- a) AHU3-4 supply fan will start regardless of the position of the 'HAND-OFF-AUTO' switch on the fan's magnetic starter and regardless of the status of low temperature thermostat and regardless of the status of the duct smoke detectors.
 - b) EF3-4 exhaust fan will start regardless of the position of the 'HAND-OFF-AUTO' switch on the fan's magnetic starter and regardless of the status of the duct smoke detectors.
 - c) The outside air damper and the exhaust air damper will fully open and the return air damper will fully close.
 - d) Smoke damper positions will be as follows;
 - SD #1 = Closed
 - SD #2 = Open
 - SD #3 = Closed
 - SD #4 = Closed
 - SD #5 = Closed

SD #6 = Closed
SD #7 = Open
SD #8 = Open
SD #9 = 20% Open
SD #10 = Closed
SD #11 = Closed

- e) The hot deck hot water valve will be commanded fully open.

TOILET EXHAUST FANS EF3-6 & 7 AND EF1-6

The toilet exhaust fans operate continuously. When the exhaust fan starts, it's respective exhaust damper opens. The fans may be started and stopped from the BMS. Fan status will be monitored by the BMS and an alarm will be indicated if the fan stops.

MEZZ. EXHAUST FANS EF3-10 & 11

When the relative humidity exceeds 60%(adjustable), as sensed by space humidity sensor the exhaust fan will be started. When the exhaust fan starts, the exhaust damper and outside air intake damper will open.

BUILDING 4

AHU4-1 (AHU4-2 Typical) EX4-X (Typical)

The occupied and unoccupied modes of operation is manually selected from the BMS.

During the occupied mode, the supply fan operates continuously and the intake air damper opens to its minimum position, as field verified.

During the unoccupied mode both fans remain off and the intake air damper closes.

Each zone temperature sensor will modulate its respective zone mixing damper to maintain the zone temp setpoint (adj.), by mixing air from the hot and cold decks.

The hot deck temperature setpoint will be reset by the zone sensor with the greatest demand for heating. The hot deck temp sensor will modulate the hot water valve to maintain the required hot deck temperature.

The cold deck temperature setpoint will be reset by the zone sensor with the greatest demand for cooling. The cold deck temp sensor will modulate the intake air damper, the mixing air damper & the exhaust air damper in sequence with the chilled water valve to maintain the required cold deck temperature.

On an initial call for cooling from the cold deck temp sensor, the intake damper will be modulated beyond its minimum position to maintain the cold deck setpoint.

Once the intake air damper is fully open and there is a continued call for cooling from the cold deck temp sensor. The chilled water valve will be modulated open to maintain the cold deck setpoint.

The position of the intake air damper is subject to a mixed air low limit temperature as sensed by the mixed air temp sensor.

When the intake air damper is modulated beyond its minimum position, EF4-X is started. When the intake air damper is at, or below, it's minimum position EF4-X is stopped.

Modulation of Intake Air Damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing dampers are allowed to modulate. When the outside air temperature is above 55 degrees, the enthalpy content of the outside air is compared to the return air. When the enthalpy content of the outside air exceeds the enthalpy content of return air, the intake air damper will be returned to and remain at a position to admit only a minimum amount of outside air for ventilation purposes and EF4-X will stop.

An outside air temperature switchover setpoint is provided. This set point is manually adjustable from the BMS. When the outside air temperature is above this setpoint, the hot water valve is not allowed to open. When the outside air temperature is below this setpoint, the chilled water valve is not allowed to open. Therefore, the unit cannot operate with mechanical heating and mechanical cooling at the same time. This setpoint will be set at 60 degrees (adjustable).

The return duct humidity will modulate the humidifier to maintain a setpoint of 40% RH (adjustable) in the return air stream.

Upon sensing an air temperature of less than 35 degrees entering the cooling coil, the freeze stat will stop the fans, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control will stop supply fan and EF4-1(2) upon activation by the building fire alarm system.

AIR HANDING UNIT AHU4-3, EF4-3

Occupied and unoccupied modes of operation will be time scheduled through the BMS.

During the occupied mode a start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of the both supply fan AHU4-3 and the return fan EF4-3, to maintain a constant supply duct static pressure as sensed by the static pressure tip located in the supply duct as shown on the drawing. Both fans operate continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck control sensor, will be reset from outside air temperature as indicated on the reset schedule. The supply air temperature will be maintained by modulating the heating valve in sequence with the outside, return & exhaust dampers and the chilled water valve.

On a call for heating, the cold water valve will be closed, the outside air damper will be at its minimum position, as field verified, and the hot water valve will be modulated open.

On a call for cooling, the chilled water valve and the hot water valve will be closed, the outside air damper will start to modulate open beyond its minimum position while the return air damper modulates closed and the exhaust air damper modulates open.

Modulation of mixing dampers is subject to a mix air low limit temperature as sensed by the cold deck temp sensor. Once the unit is operating on 100% outside air and there is a continued call for cooling, the cold water valve will be modulated.

Modulation of the mixing damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing damper is allowed to modulate. When the outside air temperature is above 55 degrees, the enthalpy content of the outside air is compared to the enthalpy content of the return air. When the enthalpy content of the outside air exceeds the enthalpy content of the return air, the mixing damper will be return to and remain at a position to admit only a minimum amount of the outside air for ventilation purpose.

Unoccupied Mode:

The supply and return fan will stop, the return air damper will open fully and the outside air and exhaust air dampers will close.

The supply and return fans will be cycled on 100% return air if any one of the terminal unit space temperature sensors, sense a space temperature of bellow 55 degree (adjustable). The speed of the fans will be controlled for 90 degrees (adjustable) while the fans are operating during the unoccupied cycle to provide heat.

An optimal start process will index the system to a warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the fans operate continuously on 100% return air.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fans, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply and return fan upon activation by the building fire alarm system.

EF4-4, EF4-5, EF4-6:

When AHU4-1 is operating, EF4-6 will start and run continuously. When AHU4-2 is operating, EF4-5 will start and run continuously. When AHU4-3 is operating in the occupied mode, EF4-4 will start and run continuously when the exhaust fan starts, its respective exhaust damper shall open.

EF4-7, EF4-8:

When the relative humidity exceeds 60% (adj.) as sensed by the Return air humidity sensor, the exhaust fan will be started. When the exhaust fan starts, the exhaust damper and intake air damper will open.

AIR TERMINAL UNIT (With reheat coil)

On a call for cooling from the space temperature sensor, the unit controller will be reset to increase the CFM through the terminal unit up to the unit's maximum CFM rating. On a call for no cooling from the space temperature sensor, the unit controller will be reset to decrease the CFM through the terminal unit down to the unit's minimum CFM rating.

On a call from heating from the space sensor, the unit controller will maintain the minimum CFM flow through the terminal unit while the reheat valve V-a is modulated to maintain space temperature.

During the morning warm up of AHU4-3, the flow through the terminal unit will be increased to its maximum CFM rating.

TOILET EXHAUST FANS EF4-4, 5 & 6

When AHU4-1 is operating, EF4-6 will start and run continuously. When AHU4-2 is operating, EF4-5 will start and run continuously. When AHU4-3 is operating in the occupied mode, EF4-4 will start and run continuously. When the exhaust fan starts, its respective exhaust damper opens.

MEZZ. EXHAUST FANS EF3-10 & 11

When the relative humidity exceeds 60%(adjustable), as sensed by exhaust duct humidity sensor the exhaust fan will be started. When the exhaust fan starts, the exhaust damper and outside air intake damper will open.

MECH/ELEC ROOM 4-152 VENTILATION

When the space temperature as sensed by the hot deck temp sensor rises above 85 degrees (adjustable), the damper located in the wall will open.

MECH/ELEC ROOM 4-121 VENTILATION

When the space temperature as sensed by the cold deck temp sensor rises above 85 degrees (adjustable), the damper located in the wall will open.

BUILDING-4 ADDITIONAL: DESCRIPTION OF OPERATION

The exhaust fan (single speed) is manually started and stopped from a switch located at the nurse's station when the fan starts, the exhaust damper is fully open. After a 2-minute delay (adjustable) commanded from the BMS. After the programmed delay, power is applied to Room Pressure Monitor to operate. The room pressure monitor monitors room pressure by measuring the amount of air flow from the corridor to the room. Upon detecting a low flow condition an audible and visual alarm will be activated on room pressure monitor.

When the exhaust fan is stopped, the exhaust damper closes fully and the room pressure monitor is disabled.

BUILDING 5

AIR HANDLING UNIT AHU5-1:

Occupied and unoccupied modes of operation will be time scheduled through BMS.

OCCUPIED MODE

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of the supply fan AHU5-1, to maintain a constant fan speed during the occupied cycle. The supply fan operates continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temp sensor, will be reset from space temperature as sensed by the mixed air temp sensor, to maintain a heating setpoint of 70 degrees (adjustable), and a cooling setpoint of 78 degrees (adjustable), in the space.

The supply air temperature will be maintained by modulating the hot water valve in sequence with the outside, return & exhaust damper and chilled water valve.

On a call for heating, the chilled water valve will be closed, the outside air damper will be at its minimum position and the hot water valve will modulated open. On a call for cooling, the chilled water valve and the hot water valve will be closed, the outside air damper will start to modulate open beyond its minimum position while the return air damper modulates closed and exhaust damper modulate open.

When the outside air damper and exhaust damper modulate open beyond minimum position, exhaust fan EF-5-1 will be started.

Modulation of mixing dampers is subject to a mix air low limit temperature as sensed by the cold deck temp sensor. Once the unit operating on 100% outside air and there is a continued call for cooling the chilled water valve will be modulated open.

Modulation of the mixing damper is subject to a dry bulb economizer. Whenever the outside temperature is below 68 degree (adjustable), the mixing dampers are allowed to modulate, and EF5-1 is allowed to start and stop. When the outside air temperature above 68 degrees the damper will be return to and remain at a position to admit only a minimum amount of air for ventilation purpose, and EF5-1 will remain off.

UNOCCUPIED MODE

The supply fan will run continuously at a reduced speed, the return air damper will open fully and the outside air damper and exhaust air damper will close. EF5-1 will remain off during the unoccupied cycle. The chilled water valve will be modulated to maintain a lower unoccupied space temperature as sensed by the mixed air temperature sensor.

An optional start process will index the system to warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the supply fan operates continuously on 100% return air at its occupied cycle speed, EF5-1 remain off.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fans, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan and EF5-1 upon activation by the building fire alarm system.

FAN COIL UNTIL FC5-1 (FC5-2, 3 & 4 TYPICAL)

Occupied and unoccupied cycles of corporation will be times schedule through FMS.

Occupied cycle

The fan coil until start and operate continuously. The outside air damper will open fully to admit a fix amount of outside air. The space temperature sensor hot deck temp sensor will modulate in sequence with the chilled water valve to maintain the desired space temperature (adj.).

Unoccupied cycle

The fan coil unit will be cycle on 100% return air and the hot water valve will modulate to maintain the unoccupied heating setpoint. Cooling will not operate.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fans, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Note, FC5-1 and FC5-2 share a common outside air damper. FC5-3 and FC5-4 share a common outside air damper.

MECHANICAL ROOM EXHAUST FAN EF5-4:

When the space temperature as sensed by the mixed air temp sensor rises above 85 degrees (adjustable), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper opens and exhaust air damper opens. When the exhaust fan stops, the outside air intake damper and the exhaust air damper close.

BUILDING 6

AIR HANDLING UNIT AHU6-1, EF6-1:

Occupied and unoccupied modes of operation will be time scheduled through BMS.

OCCUPIED MODE

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of both the supply fan AHU6-1 and the return fan EF6-1, to maintain a constant supply duct static pressure as sensed by the static pressure tip located in the supply duct as shown on the drawing. Both fans operate continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temp sensor, will be reset from outside air temperature as indicated on reset schedule. The supply air temperature will be maintained by modulating the heating valve in sequence with the outside, return & exhaust dampers and chilled water valve.

On a call for heating, the chilled water valve will be closed, the outside air damper will be at it's minimum position and the hot water valve will be modulated open.

On a call for cooling, the chilled water valve and the hot water valve will be closed, the outside air damper will start to modulate open beyond its minimum position while the return air damper modulates closed and the exhaust air damper modulates open.

Modulation of mixing dampers is subject to a mix air ow limit temperature as sensed by the cold deck temp sensor. Once the unit operating on 100% outside air and there is a continued call for cooling hot water valve will be modulated open.

Modulation of the mixing damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing damper are allowed to modulate. When the outside air temperature is above 55 degrees, the enthalpy content of the outside air is compared to the enthalpy content

of the return air. When the enthalpy content of the outside air exceeds the enthalpy content of the return air, the mixing damper will be return to and remain at a position to admit only a minimum amount of the outside air for ventilation purpose.

UNOCCUPIED MODE:

The supply and return fan will stop, the return air damper will open fully and outside air and exhaust air dampers will close.

The supply and return fans will be cycled on 100% return air if any one of the terminal unit space temperature sensors, sense a space temperature of bellow 55 degree (adjustable). The speed of the fans will be controlled for 90 degrees (adjustable) while the fans are operating during the unoccupied cycle to provide heat.

An optimal start process will index the system to a warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the fans operate continuously on 100% return air.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fans, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The freeze stat S-1 must be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply and return fan upon activation by the building fire alarm system.

AIR TEMINAL UNIT (With reheat coil)

On a call for cooling from the space temperature sensor, the unit controller will be reset to increase the CFM through the terminal unit up to the unit's maximum CFM rating.

On a call for no cooling from, the unit controller will be reset to decrease the CFM through the terminal unit down to the unit's minimum CFM rating.

On a call from heating from, the unit controller will maintain the minimum CFM flow through the terminal unit while the reheat valve V-a is modulated to maintain space temperature.

During the morning warm up of the flow through the terminal unit will be increased to its maximum CFM rating.

TOILET EXHAUST FANS EF6-2:

When AHU6-1 is indexed to occupied mode, the exhaust fan will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU6-1 is indexed to the occupied mode the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

MECHANICAL MEZZ EXHAUST FAN EF6-4:

When the space humidity as sensed by return duct humidity sensor rises above 60 percent (adjustable), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper opens and the exhaust air damper opens. When the exhaust fan stops, the outside air intake damper opens and the exhaust air damper close.

BUILDING- 7

AIR HANDLING UNIT AHU7-1 EF7-4:

Occupied and unoccupied modes of operation will be time scheduled through BMS.

Occupied mode:

A start command will be sent to the variable frequency drive, which will ramp up to speed and control speed of supply fan AHU7-1, to maintain a constant fan speed during the occupied cycle. The supply fan operates continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temp sensor, will be reset from space temperature sensed by the mixed air temp sensor, to maintain heating setpoint of 70 degrees (adjustable), and cooling set of 78 degrees (adjustable), in the space.

The supply air temperature will be maintained by modulating the heating valve in sequence with the outside return and exhaust damper and the chilled water valve.

On a call for heating the chilled water valve will be closed, the outside air damper will be at it's minimum position and hot water valve will be modulated open.

On a call for cooling the hot water valve and the chilled water valve will be closed, the outside air damper will start to modulate open beyond it's minimum position while the return air damper modulate closed and exhaust damper modulates open. When the outside air damper and exhaust damper modulate open beyond minimum position, exhaust fan EF7-4 will be started.

Modulation of the mixing damper is subject to a mixed air low limit temperature as sensed by the cold deck temp sensor. Once the unit is operating on 100% outside air and there is a continued call for cooling, the chilled water valve will modulate open.

Modulation of the mixing damper is subject to a dry bulb economizer. Whenever the outside temperature is below 68 degree (adjustable), the mixing dampers are allowed to modulate, and EF7-4 is allowed to start and stop. When the outside air temperature above 68 degrees the damper will be return to and remain at a position to admit only a minimum amount of air for ventilation purpose, and EF7-4 will remain off.

Unoccupied Mode:

The supply fan will run continuously at a reduced speed, the return air damper will open fully and the outside air damper and exhaust air damper will close. EF7-4 will remain off during the unoccupied cycle. The chilled water valve will be modulated to maintain a lower unoccupied space temperature as sensed by The mixed air temp sensor.

An optional start process will index the system to warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the supply fan operates continuously on 100% return air at it's occupied cycle speed, EF7-4 remain off.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil. The freeze stat will stop the supply fan, close the outside air damper and fully open the hot water. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan and EF5-1 upon activation by the building fire alarm system.

FAN COIL UNTIL FC7-1 (FC7-2 TYPICAL)

Occupied and unoccupied cycles of corporation will be times schedule through BMS.

Occupied cycle:

The fan coil until start and operate continuously.

Outside air damper will open fully to admit a fix amount of outside air. The space temperature sensor the hot deck sensor will modulate the hot water valve in sequence with the chilled water valve to maintain the desired space temperature.

Unoccupied cycle:

The fan coil unit will be cycle on 100% return air and the hot water valve will modulate to maintain the unoccupied heating setpoint. Cooling will not operate.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fan, close the outside damper and fully open the hot water valve. An alarm will also be indicated BMS. The freeze stat must be manually reset before the system can be restarted.

MAKE-UP AIR HANDLING UNIT MAU7-1 & HOOD FAN EF7-1

Occupied Cycle:

Whenever the kitchen hood exhaust fan, EF7-1 is manually started, exhaust damper opens fully and MAU7-1 will be indexed to the occupied cycle. MAU7-1 supply fan will start and run continuously. Outside air damper will open fully to admit 100% outside air.

The face and bypass damper will come under control of temperature hot deck sensor located in the fan discharge. The face & bypass damper will be modulated to maintain a constant supply air temperature of 55 degrees (adjustable).

Unoccupied Cycle:

When exhaust fan EF7-1 is manually stopped, the exhaust damper closes, MAU7-1 stops, and the make-up air unit outside air damper closes. MAU7-1 remains off during the unoccupied cycle.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the supply fan, close the outside air damper and fully open the chilled water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan upon activation by the building fire alarm system.

TOILET EXHAUST FANS EF7-2 AND EF7-3:

Whenever AHU7-1, FC7-1 or FC7-2 is operating in the occupied mode. EF7-2 will start and run continuously. When EF7-2 starts, the exhaust damper will open fully. When AHU7-1, FC7-1 and FC7-2 are not operating in the occupied mode, EF7-2 will remain off and the exhaust damper will remain close.

Whenever MAU7-1 is operating in the occupied mode, EF7-3 will start and run continuously. When EF7-3 starts, the exhaust damper will open fully. When MAU7-1 is not operating in the occupied mode EF7-3 will remain off and the exhaust damper remain closed.

MEZZ. EXHAUST FAN EF7-5

When the relative humidity exceeds 60%(adjustable), as sensed by exhaust duct humidity sensor the exhaust fan will be started. When the exhaust fan starts, the exhaust damper and outside air intake damper will open.

BUILDING 8

AIR HANDLING UNIT AHU8-1 EF-8:

Occupied and unoccupied cycles of operation will be time scheduled through BMS.

Occupied Mode:

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of both the supply fan AHU8-1 and the return fan EF8-1, to maintain a constant supply duct static pressure as sensed by the static pressure tip located in the supply duct as shown on the drawing. Both fans operate continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temp sensor, will be reset from outside air temperature as indicate by the rese schedule the supply air temperature sensor will be maintained by modulating heating valve in sequence with the outside, return & exhaust damper and chilled water valve. On a call for heating, the chilled water valve will be closed, the outside air damper will be at its minimum position and the hot water valve will be Modulated open. On a call for cooling the chilled water and hot water valve will be closed, the outside air damper will start to modulate open beyond its minimum position while the return air damper modulates closed and exhaust Modulation of mixing dampers is subject to a mix air ow limit temperature as

sensed by the cold deck temperature sensor. Once the unit operating on 100% outside air and there is a continued call for cooling cold water valve will be modulated open.

Modulation of the mixing damper is subject to an enthalpy and temperature comparison. Whenever the outside air temperature is below 55 degrees, the mixing damper are allowed to modulate. When the outside air temperature is above 55 degrees, the enthalpy content of the outside air is compared to the enthalpy content of the return air. When the enthalpy content of the outside air exceeds the enthalpy content of the return air, the mixing damper will be return to and remain at a position to admit only a minimum amount of the outside air for ventilation purpose.

Unoccupied Mode:

The supply and return fan will stop, the return air damper will open fully and outside air and exhaust air dampers will close.

The supply and return fans will be cycled on 100% return air if any one of the terminal unit space temperature sensors, sense a space temperature of bellow 55 degree (adjustable). The speed of the fans will be controlled for 90 degrees (adjustable) while the fans are operating during the unoccupied cycle to provide heat.

An optimal start process will index the system to a warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the fans operate continuously on 100% return air.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fans, close the outside air damper and fully open hot water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply and return fan upon activation by the building fire alarm system.

AIR TEMINAL UNIT (Without reheat coil)

On a call for cooling from the space temperature sensor, the unit controller will be reset to increase the CFM through the terminal unit up to the unit's maximum CFM rating. On a call for no cooling from space temperature sensor, the unit controller will be reset to decrease the CFM through the terminal unit down to the unit's maximum CFM rating.

AIR TEMINAL UNIT (With reheat coil)

On a call for cooling from the space temperature sensor, the unit controller will be reset to increase the CFM through the terminal unit up to the unit's maximum CFM rating. On a call for no cooling from the space temperature sensor, the unit controller will be reset to decrease the CFM through the terminal unit down to the unit's minimum CFM rating.

On a call from heating from space heating temperature sensor, the unit controller will maintain the minimum CFM flow through the terminal unit while the reheat valve V-a is modulated to maintain space temperature.

During the morning warm up of AHU4-3, the flow through the terminal unit will be increased to its maximum CFM rating.

FAN COIL UNTIL FC8-1

Occupied and unoccupied cycles of corporation will be times schedule through BMS.

Occupied cycle

The fan coil until start and operate continuously.

Outside air damper will open fully to admit a fix amount of outside air.

The space temperature sensor hot deck temp sensor will modulate the hot water valve in sequence with chilled water valve to maintain the desired space temperature.

Unoccupied cycle

The fan coil unit will be cycle on 100% return air and the heating hot water valve will modulate to maintain the unoccupied heating setpoint. Cooling will not operate.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil, the freeze stat will stop the fan, close the outside damper and fully open the hot water valve. An alarm will also be indicated BMS. The freeze stat must be manually reset before the system can be restarted.

FAN COIL UNTIL FC8-2

Occupied and unoccupied cycles of corporation will be times schedule through BMS.

Occupied cycle

The fan coil until start and operate continuously.

The space temperature sensor Hot water deck temp sensor will modulate the hot valve in sequence hot water valve to maintain the desired space temperature.

Unoccupied cycle

The fan coil unit will be cycle and the hot water valve will modulate to maintain the lower unoccupied heating setpoint. Cooling will not operate.

TOILET EXHAUST FANS EF8-2 & 3:

When AHU8-1 is indexed to occupied mode, the exhaust fan will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU8-1 is indexed to the occupied mode the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

MECHANICAL ROOM EXHAUST FAN EF8-5

When the space temperature as sensed by hot deck temp sensor rises above 55 degrees (adjustable), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper opens and exhaust air damper opens. When the exhaust fan stops, the intake and exhaust dampers close.

BUILDING 9A

AIR HANDLING UNIT AHU9A-1, AHU9A-2,

Occupied and unoccupied cycles of operation will be time scheduled through the BMS.

Occupied cycles:

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of the supply fan AHU9A-1, to maintain a constant supply duct static pressure tip located in the supply duct as shown on the drawing. The supply fan operations continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temperature sensor, will be reset from outside air temperature as indicated on the reset schedule shown on the heating valve chilled water valve in sequence with the outside & return dampers and chilled water . On a call for heating, hot water valve will be closed, the outside air damper will be at its minimum position and chilled water valve will be modulated open, on a call for cooling, chilled water valve and hot water valve will be closed, the outsider air damper will start modulate open beyond its minimum position while the return air damper modulates closed. Modulation of mixing dampers is subject to a mixed air low limit temperature as sensed by the cold deck temperature sensor. Once the unit is operating on 100% outside air and there is a continued call for Cooling, hot water valve will modulated open.

Modulation of the mixing dampers is subject to a dry bulb economizer. Whenever the outside air temperature is below 68 degrees (adjustable), the mixing damper are allowed to modulate. When the outside air

temperature is above 68 degrees the mixing dampers will be returned to and remain at a position to admit only a minimum amount of outside air for ventilation purposes.

Unoccupied cycle:

The supply fan will run continuously at a reduced speed; the return air damper will open fully and the outside air damper and exhaust air damper will close. EF9A-4 will remain off during the unoccupied cycle. Chilled water valve will be modulated to maintain a lower unoccupied space temperature as sensed by the mixed air temperature sensor.

An optional start process will index the system to warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the supply fan operates continuously on 100% return air at it's occupied cycle speed, EF9A-4 remain off.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil. The freeze stat will stop the supply fan, close the outside air damper and fully open the chilled water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan upon activation by the building fire alarm system.

AIR TERMINAL UNIT (With Reheat Coil and Parallel Fan)

On a call for cooling from the space temperature sensor, the unit controller will be reset to increase the CFM through the terminal unit up to the unit's maximum CFM rating. On a call for no cooling from the space temperature sensor, the unit controller will be reset to decrease the CFM through the terminal unit down to the unit's minimum CFM rating.

On a call from heating from the space temperature sensor, the unit controller will maintain the minimum CFM flow through the terminal unit from the primary fan system and start the terminal unit parallel fan to recirculate return air from above the ceiling. On continued call for heat, the reheat valve V-a is modulated to maintain space temperature.

During the unoccupied cycle the heating setpoint for the terminal unit is lower and parallel fan and reheat coil will be cycled to maintain the lower unoccupied setpoint.

During the morning warm up of AHU4-3, the flow through the terminal unit will be increased to it's maximum CFM rating.

AIR HANDLING UNIT AHU9A-1, 9A-2

Occupied cycle:

Whenever anyone of the five kitchen hood exhaust fans, EF9A-1 through EF9A-5 is manually started, AHU9A-2 will be indexed to the occupied Cycle.

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of the supply fan AHU9A-2.the frequency drive. The supply fan operates continuously during the occupied cycle, as long as any one of the five hood fans is operating.

When started in the occupied cycle, the outsider air damper will open filly and the return air damper will close fully. The system will operate using 100% outside air.

The supply air temperature, as sensed by the hot deck temp sensor, will be reset from space temperature as sensed by the cold deck temp sensor, the supply air temperature will be maintained by modulating the heating valve.

Unoccupied cycle:

Whenever the all of the five kitchen hood exhaust fans, EF9A-1 through EF9A-1 are manually stopped, AHU9A-2 will be induced to the unoccupied cycle.

The supply fan will stop, the return air damper will open full the outside air damper will close. Upon a call for heating from space temperature sensor the hot deck temp sensor, the supply fan will be cycled on full heat and 100% return air to maintain to the lower unoccupied temperature setting.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil. The freeze stat will stop the supply fan, close the outside air damper and fully open fully hot water valve. Air alarm will also be indicated at the FMS, The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop the supply fan upon activation by the building fire alarm system.

FAN COIL UNTIL FC9A-1 (FC9A-2 Typical)

Occupied and unoccupied cycles of corporation will be times schedule through BMS.

Occupied cycle:

The fan coil until start and operate continuously.

The space temperature sensor hot deck sensor will modulate hot water valve in sequence with chilled water valve to maintain the desired space temperature.

Unoccupied cycle:

The fan coil unit will be cycle and HOT WATER VALVE will modulate to maintain the lower unoccupied heating setpoint. Cooling will not operate.

KITCHEN HOOD FANS

The kitchen hood fans consist of an exhaust fan and an associated make-up air handing unit. They are interlocked in pairs as follows:

EF9A-1---MAU9A-1
EF9A-2---MAU9A-2
EF9A-3---MAU9A-3
EF9A-4---MAU9A-4
EF9A-5---MAU9A-5

The exhaust fan is started and stopped manually via a local on/off switch. When the exhaust fan is started, it's associated make-up air unit is interlocked to start. When exhaust fan starts, the exhaust damper open fully. When the make-up air unit starts, outside air damper opens fully and the heating valve comes under control of temperature sensor hot deck temp sensor located in the heating coil discharge. the hot water valve will be modulated to maintain a constant supply air temperature of 90 degrees (adjustable).

When the exhaust fan is manually stopped, the exhaust damper closes, the associated make-up air unit stops, and the make-up air unit outside air damper closes.

The exhaust fans are interlocked with the kitchen hood fire suppression system.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil. The freeze stat will stop the supply fan, close the outside air damper and fully open the hot water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan upon activation by the building fire alarm system.

TOILET EXHAUST FANS EF8-2 & 3:

When AHU8-1 is indexed to occupied mode, the exhaust fan will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU8-1 is indexed to the occupied mode the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

EXHAUST FANS EF9A-7, 8 & 9

These exhaust fans are manually started and stopped via a local wall switch. When the fan starts, it's respective exhaust damper opens.

ELECTRICAL ROOM EXHAUST FAN EF9A-10

When the space temperature as sensed by hot deck temp sensor rises above 85 degree (adjustable), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper opens and the exhaust air damper opens. When the exhaust fan stops, the intake and exhaust dampers close.

MECHANICAL ROOM EXHAUST FAN EF9A-11

When the space temperature as sensed by hot deck temp sensor rises above 85 degree (adjustable), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper opens and the exhaust air damper opens. When the exhaust fan stops, the intake and exhaust dampers close

CORRIDOR 9A-101 HEAT AND VENTILATION (CORRIDOR 9A-100 Typical)

On a call for cooling from two stage thermostats, exhaust fan EF9A-1 will start, exhaust damper and outside air intake damper will open. Unit heaters UH-3 & 4 will be off. As the space temperature decrease EF9A-1 will stop, the intake and exhaust dampers will close and unit UH-3 & 4 will remain off.

On a call for heating from aqua stat, unit heater UH-3 & 4 will be cycled on, subject to their respective strap-on aqua stat. EF9A-1 will be off. Note, EF9A-2 and UH9A-1 & 2 serve corridor 9A-100.

BUILDING 9B

AIR HANDLING UNIT AHU9B-1, AHU9B-2,

Occupied and unoccupied cycles of operation will be time scheduled through the BMS.

Occupied and unoccupied cycles of operation will be time scheduled through the BMS.

Occupied cycles:

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of the supply fan AHU9A-1, to maintain a constant supply duct static pressure tip located in the supply duct as shown on the drawing. The supply fan operations continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temperature sensor, will be reset from outside air temperature as indicated on the reset schedule shown on the heating valve chilled water valve in sequence with the outside & return dampers and chilled water . On a call for heating, hot water valve will be closed, the outside air damper will be at its minimum position and chilled water valve will be modulated open, on a call for cooling, chilled water valve and hot water valve will be closed, the outsider air damper will start modulate open beyond its minimum position while the return air damper modulates closed. Modulation of mixing dampers is subject to a mixed air low limit temperature as sensed by the cold deck temperature sensor. Once the unit is operating on 100% outside air and there is a continued call for Cooling, hot water valve will modulated open.

Modulation of the mixing dampers is subject to a dry bulb economizer. Whenever the outside air temperature is below 68 degrees (adjustable), the mixing damper are allowed to modulate. When the outside air temperature is above 68 degrees the mixing dampers will be returned to and remain at a position to admit only a minimum amount of outside air for ventilation purposes.

Unoccupied cycle:

Both the supply and exhaust fans will stop; the return air damper will open fully and the outside air damper and exhaust air damper will close. The supply and exhaust fans will remian off during the unoccupied cycle.

An optional start process will index the system to warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the supply and exhaust fans operates continuously on 100% return air.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil. The freeze stat will stop the supply fan, close the outside air damper and fully open the chilled water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan upon activation by the building fire alarm system.

MECHANICAL ROOM EXHAUST FAN EF9B-2

When the space temperature as sensed by hot deck temp sensor rises above 85 degree (adjustable), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper opens and the exhaust air damper opens. When the exhaust fan stops, the intake and exhaust dampers close

TOILET EXHAUST FANS EF9B-1, 5, 6, 7 AND 8

When AHU9B-2 is indexed to the occupied mode, the exhaust fans will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU9b-1 is indexed to the unoccupied mode, the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

TOILET EXHAUST FANS EF9B-4 AND 9

When AHU9B-1 is indexed to the occupied mode, the exhaust fans will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU9b-1 is indexed to the unoccupied mode, the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

BUILDING 9C

AIR HANDLING UNIT AHU9C-1, AHU9C-2,

Occupied and unoccupied cycles of operation will be time scheduled through the BMS.

Occupied and unoccupied cycles of operation will be time scheduled through the BMS.

Occupied cycles:

A start command will be sent to the variable frequency drive, which will ramp up to speed and control the speed of the supply fan AHU9A-1, to maintain a constant supply duct static pressure tip located in the supply duct as shown on the drawing. The supply fan operations continuously during the occupied cycle.

The supply air temperature, as sensed by the hot deck temperature sensor, will be reset from outside air temperature as indicated on the reset schedule shown on the heating valve chilled water valve in sequence with the outside & return dampers and chilled water . On a call for heating, hot water valve will be closed, the outside air damper will be at its minimum position and chilled water valve will be modulated open, on a call for cooling, chilled water valve and hot water valve will be closed, the outsider air damper will start modulate open beyond its minimum position while the return air damper modulates closed. Modulation of mixing dampers is subject to a mixed air low limit temperature as sensed by the cold deck temperature sensor. Once the unit is operating on 100% outside air and there is a continued call for Cooling, hot water valve will modulated open.

Modulation of the mixing dampers is subject to a dry bulb economizer. Whenever the outside air temperature is below 68 degrees (adjustable), the mixing damper are allowed to modulate. When the outside air temperature is above 68 degrees the mixing dampers will be returned to and remain at a position to admit only a minimum amount of outside air for ventilation purposes.

Unoccupied cycle:

Both the supply and exhaust fans will stop; the return air damper will open fully and the outside air damper and exhaust air damper will close. The supply and exhaust fans will remian off during the unoccupied cycle.

An optional start process will index the system to warm up mode prior to the scheduled occupancy time based on space temperature and outside air temperature. During the warm up mode, the supply and exhaust fans operate continuously on 100% return air.

Upon sensing a leaving air temperature of less than 35 degrees from the heating coil. The freeze stat will stop the supply fan, close the outside air damper and fully open the chilled water valve. An alarm will also be indicated at the BMS. The freeze stat must be manually reset before the system can be restarted.

Fire alarm control relays will stop supply fan upon activation by the building fire alarm system.

MAKE UP AIR UNIT MAU9D-1 AND EXHAUST FAN EF9D-6

EF9D-6 is manually started and stopped by indexing an existing selector switch with shall remain and be reused. When EF9D-6 starts, the exhaust air damper closes. The fan will be started and the VFD will begin to ramp to control CFM. When MAU9D-1 starts the outside air damper opens fully and the return air damper closes fully, the system operated using 100% outside air. The supply air temperature will be controlled to maintain a constant 85F (adj.) by modulating the hot water valve.

When EF9d-6 is stopped, MAU9D-1 will stop and the outside air damper will close and the return damper will open.

Upon sensing a leaving air temperature of less than 35F (adj.) from the heating coil, the low temperature limit will stop the supply fan, close the outside air damper and fully open the heating coil control valve. An alarm will also be indicated at the operator work station. The low limit temperature sensor must be manually reset.

Fire alarm control relay (existing) will stop MAU9d-1 fan upon activation by the building fire alarm system.

ELECTRIC ROOM EXHAUST FANS EF9C-3

When space temperature thermostat senses a rise above 85F (adj.), the exhaust fan will be started. When the exhaust fan starts, the outside air intake damper and exhaust dampers open. When the exhaust fan stops the outdoor air and exhaust air dampers close fully.

TOILET EXHAUST FANS EF9D-1, 2, 3, 4, 5 AND 7

When AHU9C-1 or AHU9C-2 is indexed to the occupied mode, the exhaust fans will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU9C-1 or AHU9C-2 is indexed to the unoccupied mode, the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

TOILET EXHAUST FANS EF9C-4

When AHU9C-3 or AHU9C-4 is indexed to the occupied mode, the exhaust fans will start and operate continuously. When the exhaust fan starts, the exhaust damper opens fully. When AHU9C-1 or AHU9C-2 is indexed to the unoccupied mode, the exhaust fan will stop and remain off. When the exhaust fan stops, the exhaust damper closes.

BUILDING 10A

AIR HANDLING UNIT 10A-1

Unit will be indexed occ/unocc by optimal start program in the BMS.

Occupied cycle:

Unit supply fan shall run subject to the low temperature thermostat shutdown interlock. The outside air damper shall open fully and the room thermostat shall modulate the heating coil control valve to maintain space temperature set point (adj.). If the space temperature gets to be above 76F the outside air damper will close and the D/X coil will be indexed on with the heating valve fully closed.

Unoccupied cycle:

Unit will cycle on with the outside air damper closed to maintain setback setpoint.

EF10A-1 will start and run continuously in occupied mode and will stop in the unoccupied mode.

AIR HANDLING UNIT 10A-2 (Roof Top Unit)

Unit will be indexed occ/unocc by optimal start program in the BMS.

Occupied cycle:

Unit supply fan shall run subject to the low temperature thermostat and smoke detector (existing to remain) shutdown interlock. The outside air damper will open to its minimum position and the room thermostat will modulate the heating coil control valve to maintain an adjustable space temperature setpoint.

Unoccupied cycle:

Unit will cycle on with the outside air damper closed only to maintain setback setpoint.

MAKEUP AIR UNIT 10A-1

100 percent outdoor air make-up unit (MAU10-1) will be interlocked to run when the paint booth exhaust fan is energized, locally switched (existing switch to remain and be reused). When the paint booth exhaust fan is switched on, the outside air damper will open and the fan will run continuously. The discharge air sensor will modulate the heating coil control valve to maintain the discharge air at 90F (adj..). When the outside air temperature is above 65F (adj.) the heating coil control valve will remain closed.

EF10A-4 will run continuously. In the event that the fan fails, current sensor will initiate an alarm as the operator work station.

BUILDING 11

AIR HANDLING UNIT AHU11-1

The system will be indexed occ/unocc by the BMS optimal start program.

Occupied cycle: (Warm up / Cool Down):

The unit supply fan will be energized, subject to low temperature and smoke detector permissive, and the vfd will be commanded to ramp up and the modulated to maintain the scheduled CFM setpoint. The heating / cooling coil valves and the outside air/return air dampers will be modulated to maintain the discharge air temperature reset set point (adj.). Modulating the mixing dampers is subject to enthalpy economizer. When below 68F, outside air temperature ef11-1 will start when outside air dampers are at 100%. EF11-1 will be off above 68F outside air temperature.

In the heating mde the average space temperature will reset the discharge air temperature by modulating the heating coik controld valve to maintain the following schedule (adj.):

| | |
|-----------|---------------|
| Space 75F | Discharge 55F |
| Space 65F | Discharge 95F |

In the cooldown mode the average space temperature will reset the discharge air temperature by modulating the coolin coil control valve or the economizer dampers as required for the following schedule (adj.)

| | |
|-----------|---------------|
| Space 85F | Discharge 55F |
| Space 75F | Discharge 65F |

In the unoccupied mode the fans will run with the FVD setback to scheduled CFM and the outside air dampers will remain closed. If the space temperature falls below setpoint, the heating coil control valve will modulate open to maintain the setback space setpoint (adj.)

FAN COIL UNTIL FC11-1, FC11-2, 3

Occupied and unoccupied cycles of corporation will be times schedule through FMS.

Occupied cycle

The unit fan will start and run continuously subject to the low temperature thermostat permissive. The outdoor air damper will open and the heating coil and cooling coil control valves will be modulated in sequence to maintain space temperature setpoints (adj.).

If the low temperature thermostats limit is exceeded, the fan will shut down, the outside air damper will close and the heating coil valve will go full open to the coil. An alarm will be sent to the operative work station upon fan failure to start.

Unoccupied cycle

The outdoor air damper will remain closed; the heating coil control valve will be modulated and the fan will cycled to maintain setback space temperature setpoint (adj.)

EF11-2, 3 will start and run continuously in the occupied mode only

BUILDING 12

AIR HANDLING UNIT AHU12-1

The system will be indexed occ/unocc by the BMS optimal start program.

The system will be indexed occ/unocc by the BMS optimal start program.

Occupied cycle: (Warm up / Cool Down):

The unit supply fan will be energized, subject to low temperature and smoke detector permissive, and the vfd will be commanded to ramp up and the modulated to maintain the scheduled CFM setpoint. The heating / cooling coil valves and the outside air/return air dampers will be modulated to maintain the discharge air temperature reset set point (adj.). Modulating the mixing dampers is subject to enthalpy economizer. When below 68F, outside air temperature EF12-5 will start when outside air dampers are at 100%. EF12-5 will be off above 68F outside air temperature.

In the heating mode the average space temperature will reset the discharge air temperature by modulating the heating coil control valve to maintain the following schedule (adj.):

| | |
|-----------|---------------|
| Space 75F | Discharge 55F |
| Space 65F | Discharge 95F |

In the cooldown mode the average space temperature will reset the discharge air temperature by modulating the cooling coil control valve or the economizer dampers as required for the following schedule (adj.)

| | |
|-----------|---------------|
| Space 85F | Discharge 55F |
| Space 75F | Discharge 65F |

In the unoccupied mode the fans will run with the FVD setback to scheduled CFM and the outside air dampers will remain closed. If the space temperature falls below setpoint, the heating coil control valve will modulate open to maintain the setback space setpoint (adj.)

EF12-2, EF12-4 Control:

The fans will start and the dampers will open in the occupied mode. In the unoccupied mode the dampers will close and the fans will be de-energized.

FAN COIL UNTIL FC12-1, 2

Occupied and unoccupied cycles of corporation will be times schedule through FMS.

Occupied cycle

The unit fan will start and run continuously subject to the low temperature thermostat permissive. The outdoor air damper will open and the heating coil and cooling coil control valves will be modulated in sequence to maintain space temperature set points (adj.).

If the low temperature thermostats limit is exceeded, the fan will shut down, the outside air damper will close and the heating coil valve will go full open to the coil. An alarm will be sent to the operator work station upon fan failure to start.

Unoccupied cycle

The outdoor air damper will remain closed; the heating coil control valve will be modulated and the fan will cycled to maintain setback space temperature setpoint (adj.)

MAKEUP AIR UNIT MAU12-1

100 percent outdoor air make-up unit (MAU11-1) will be interlocked to run when the paint booth exhaust fan is energized, locally switched (existing switch to remain and be reused). When the paint booth exhaust fan is switched on, the outside air damper will open and the fan will run continuously. The discharge air sensor will modulate the heating coil control valve to maintain the discharge air at 90F (adj.). When the outside air temperature is above 65F (adj.) the heating coil control valve will remain closed.

EF12-1 will start and the damper will open in the occupied mode and the reverse sequence in the unoccupied.

BUILDING 13

AIR HANDLING UNIT AHU13-1

The system will be indexed occ/unocc by the BMS optimal start program.

Occupied cycle: (Warm up / Cool Down):

The unit supply and return fans will be energized, subject to low temperature and smoke detector permissive, and the VFD will be commanded to ramp up and the modulated to maintain the scheduled CFM setpoint. The outdoor air/return air dampers will modulate in economizer cycle subject to the enthalpy control program.

In the heating mode the average space temperature will reset the discharge air temperature by modulating the heating coil control valve to maintain the following schedule (adj.):

| | |
|-----------|---------------|
| Space 75F | Discharge 55F |
| Space 65F | Discharge 95F |

In the cooldown mode the average space temperature will reset the discharge air temperature by modulating the cooling coil control valve or the economizer dampers as required for the following schedule (adj.)

| | |
|-----------|---------------|
| Space 85F | Discharge 55F |
| Space 75F | Discharge 65F |

In the unoccupied mode the fans will run with the FVD setback to scheduled CFM and the outside air dampers will remain closed. If the space temperature falls below setpoint, the heating coil control valve will modulate open to maintain the setback space setpoint (adj.)

Terminal Unit (TU13-1 thru TU13-16)

The space temperature sensor will control the damper actuator. When the space temperature rises above its setpoint the damper will open and when the setpoint is reached the damper will return to the minimum position. During morning warm-up the damper will go fully open.

EF13-2 and EF13-4 Control:

In the occupied mode the exhaust fans will be energized and their respective dampers will open.