



Addendum #1
BID #2875
Refinishing Gymnasium Floors
Hamden, Connecticut

Question #1: There are no measurements listed for Wintergreen School or for Spring Glen elementary. Are those measurements available?

Answer #1:

- Spring Glen Elementary School
**1908 Whitney Avenue
Hamden, CT 06517
80 ft long x 50 ft wide

- *Wintergreen School
670 Wintergreen Avenue
Hamden, CT 06514
84 ft x 50 ft wide

Question #2: 4/6 schools are listed with a single asterisk and two have no asterisk, the only legend states a double asterisk is for a full re sand and it appears as if you are only looking for a maintenance coat in the bid however it is not clear from reading it.

Answer #2:

- * Screen, tack and apply one finish on the gym floor.
- ** Sand floor to bare wood. Apply two (2) coat oil based finish using Bona Sport Seal or approved equal. Paint game lines as preexisted before sanding using Bona Court Lines Sports Floor Paint or approved equal. Complete as follows: Two (2) Coat of Bona Oil Sports Sealer, one (1) coats of Court Line Paint, two (2) coats of Poly 350

Question #3: I'd also like to know if an on-site inspection can be arranged prior to the bid opening to clarify the work entailed and to verify the measurements.

Answer #3: Call Frank Caraglio 203 407 2234 for an on-site visit.

End of Addendum #1

April 23, 2019