

PROJECT #19MIL22301

JUNE 18, 2019

ADDENDUM #5

PROJECT NAME: BOILER AND WATER HEATER REPLACEMENT AT NEW LONDON ARMORY

SUBJECT: TEMPORARY HEAT CLARIFICATION

Original Bid Due Date / Time: May 29, 2019 2:00 pm **changed from June 19, 2019 2:00PM**

To June 26, 2019 2:00PM

The bid dates are not changed by this addendum

To: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this project referenced above. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on Section 00 41 00 Bid Proposal Form. Failure to do so may subject Bid Proposers to disqualification.

Addendum Item 1:

Temporary heat clarification:

Temporary heating will be required. The contractor shall be responsible to provide all material, equipment, labor and costs required to maintain a minimum building space temperature of 68-degree F during cold weather operations. Size based on the new boilers.

Temporary domestic hot water will be required. The contractor shall be responsible to provide all material, equipment, labor and costs required to provide domestic hot water to the facility at all times. Size to match the existing water heater. The contractor will be responsible for the fuel costs.



Ronna Cannata, Purchasing Supervisor