

ADDENDUM #2



**New Ceiling – Lead the Way Lab:
Wooster Middle School**

150 Lincoln Street
Stratford, CT 06614

TOWN PROJECT NUMBER: 2019-033

ISSUED: 5/16/2019

PROJECT TEAM

Architect / Project Manager

SNYDER
ARCHITECTS, LLC

Architecture . Planning . Construction Management

Trumbull, CT 203-243-3346
info@snyderarchitects.com

The work shall be carried out in accordance with the following supplemental instructions and in accordance with the Contract Documents.

MISCELLANEOUS CHANGES / CLARIFICATION

1. Requests for Information (RFI) Log:

- See attached updated RFI Log.

***** END OF ADDENDUM #2 *****

RFI LOG					
New Ceiling - Lead the Way Lab:					
Wooster Middle School					
Date: 5/13/2019					
	Question	Date Received	Directed To	Response	Response Date
1	Please clarify Warrantee/Guarantee as two sections are conflicting (Architects notes and Instructions to Bidders). General Note #12 – Drawing T-001 requests a 5 year installation warrantee and the instructions to bidders states “one (2) years defective material and workmanship”. We ask 1) for clarification as to which statement takes precedent and 2) if needed the definition of one (2) years. Thank you.	5/10/2019	Snyder	The intent is that the contractor shall provide a 2-year labor and material warranty for the project per Supplementary Conditions.	5/13/2019
2	What is the desired head type for the new sprinkler heads?	5/14/2019	Snyder	Contractor shall provide signed and sealed engineered sprinkler system drawings documenting required system modifications for permitting. Sprinkler heads shall be Recessed Pendent type with white trim.	5/16/2019
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					