



MEMORANDUM NO. 1

To: All Bidders for Bid Package 1.03 – Plumbing, Mechanical, Fire Protection

From: Dan Hetzler, Preconstruction Manager
O & G Industries, Inc.

Subject: Woodrow Wilson Middle School – Phase I
Middletown, Connecticut
State Project No. 083-0116N

Date: June 7, 2019

Listed below are further clarifications and/or revisions to the contract documents. The contents of this Memorandum will be included in the contract of the successful contractor. This Memorandum does not have to be acknowledged on the bid form.

The supplemental information for Bid Package 1.03 – Plumbing, Mechanical, Fire Protection is as follows:

The DOAS unit specified within division 23 shall be a complete operational system including condensing section. The unit may be a single packaged device or combination split air handler with remote condensing unit. The mechanical contractor shall provide a complete system along with any necessary mounting, flashing, interconnecting piping, and interconnecting wiring.

DH/lab
CC: File