

Generator Replacement
Town of Orange
Police Station
314 Lambert Road

Responses to Bidders' Questions # 1
07-19-19

1. Could you please let me know if prevailing wage rates apply to this project?

Prevailing wages would only apply if the contract were over \$100,000.

2. For the Orange PD Generator Bid Line item 12 in scope of work has us retapping and changing generator voltage on existing generator per manufacturer procedure. Can you provide the existing generator nameplate information mainly model # and serial # so we can coordinate with the manufacturer accordingly. Thank you.

Attached is a photo showing the existing police station generator nameplate.

KOHLER

KOHLER CO. KOHLER WI. USA

MODEL 150R0ZJ


SERIAL 395838

SPEC. PA-189828

SERVICE DUTY: STANDBY

HZ: 60 RPM: 1800 FUEL:

			KW	KVA	P.F.
SINGLE PHASE					
THREE PHASE			150.00	188.00	.8
VOLTAGE (CODE)	120/240 (61) 1p	139/240 (51)	127/220 (51)	120/240 (01)	
AMPS					
277/480 (71)	220/380 (71)	120/208 (81)	347/600 (91)	110/220 (01)	110/190 (51)
		520.00			
110/220 (51) 1p	230/400 (71)	240/416 (71)			
GEN. MODEL:			BATT. 12 V		
INSULATION: NEMA CLASS			H		



KOHLER

FOR SALES &



IN THE U.S. & C

1-800-544-