

Addendum #1- Responses to Requests for Information

Invitation to Bid #1764-19  
Pitkin School Roof Replacement Project

Posting Date 9/27/2019

*Note: If similar questions were received by multiple parties, questions were combined to form one question representing intent and answered below.*

- 1) Is there a specific shingle manufacturer requested?
  - a. GAF "Timberline HD". Please refer to Section 073113 of the Project Manual for detailed product specifications.
  
- 2) What type of warranty is required?
  - a. Please refer to Section 073113 of the Project Manual for full warranty requirements.
  
- 3) Is there existing ice and water barrier or does it need to be applied?
  - a. The existing roof system will be demolished down to the roof deck, so any existing ice and water barrier will be removed. Reference drawing A3.1 for details of new roofing system (including underlayment's), as well as Division 7 of the Project Manual for all specifications.
  
- 4) Where is an ok location to put the dumpster?
  - a. This will be determined during the pre-construction coordination meeting. There are various locations around the school where dumpsters can be located for ease of loading.
  
- 5) What is your preferred schedule for the job?
  - a. It is the intention of East Hartford Public Schools to have this work performed as soon as possible. Per the Invitation to Bid, the project must be completed within 7 weeks of the mutually agreed upon project start date. The project start date will be agreed upon prior to execution of a construction contract.
  
- 6) What is the current prevailing wage for East Hartford.
  - a. Please reference the prevailing wage schedule received from the CT Department of Labor dated 8-20-2019 that is part of the bid documents posted on the EHPS website: <https://www.easthartford.org/cms/one.aspx?pagelId=19785688>