

**MUNICIPAL CENTER PEDESTRIAN PATHWAY
ADDENDUM NO. 1
October 7, 2019**

TO ALL BIDDERS:

All instructions contained in this addendum shall be reflected in the Bid and will be made part of the Contract Documents when the Contract is awarded. Sealed bids are still due to be received at the office of the Town Manager of the Town of Tolland located at the Tolland Town Hall, 21 Tolland Green, Tolland, CT 06084, until **2:00 PM prevailing time on Thursday October 10, 2019**, at which time the bids will be opened publicly and read aloud. Bids received after the Bid Opening date and/or time will be returned unopened.

Bids submitted shall be deemed to include the Contract Document information as shown in Addendum No. 1. General bidders shall notify sub-bidders that may be affected by this addendum as applicable. Bidders shall be required to acknowledge receipt of this Addendum in the space provided on the Bid Proposal Form, Page BP-1. Failure to acknowledge this Addendum by the Bidder may result in the rejection of their bid. Bidders are directed to review changes to all portions of the work as changes to one portion may affect the work of another.

The following items form this addendum:

Responses to questions posed:

Question 1- Due to winter approaching will the seeding and planting be allowed to be completed in the spring?

Response- Final planting may be performed in the spring if late season weather conditions are not favorable however, if grass seed is not established this year the contractor will be required to place a temporary seed/mulch on all disturbed areas to minimize erosion during the winter months. The method of temporary seed/mulch shall be suggested by the contractor and reviewed/approved by the Town prior to placement.

Question 2- Is it the Town's intent to have the pavement in place this year?

Response- It is the Town's intent to pave this project this year however 45 degree ambient temperature must be present in order to pave therefore the paving schedule will be dependent on the progress of work and weather.

END OF ADDENDUM No. 1