

TOWN OF COLCHESTER, CONNECTICUT  
RFP 2019-08 D.P.W. COLCHESTER WATER DIVISION  
WELL 3A – PUMP HOUSE AND ASSOCIATED PIPING

.....

To be considered as part of the contract drawings and specifications for the Town of Colchester Well 3A – Pump House and Associated Piping:

**CONTRACT SPECIFICATION EDITS**

**SECTION 13430 – CONTROL PANELS**

1. Page 13430-3, DELETE Paragraph 2.02 B. and replace with “Maple Systems, HMI Series, no equal, to ensure compatibility with existing HMI/OIT.”

**SECTION 13440 – PROGRAMMABLE CONTROLLERS**

1. Page 13440-5, DELETE Paragraph 2.02 G. and replace with “The PLCs/RTUs shall be compatible with the specified SCADA network and existing PLC/RTUs. The RTUs shall be manufactured by Emerson ControlWave, no equal, to ensure compatibility with existing RTU.