



Central Connecticut State University

Start with a Dream. Finish with a Future.

Purchasing Department

**Request for Proposal # 2020-17
Campus Water Management/Treatment Program
Addendum 2 dated February 5, 2020**

Addendum 2 answers questions submitted regarding the subject RFP

22 Out Buildings Only

- What is the service visit frequency required? (Monthly should be adequate)
REPLY: Per section 2.4.8 of the RFP CCSU is requiring twice monthly service visits
- Spec calls for twice monthly
REPLY: No they are not.
- Are the out buildings presently serviced twice per month- looking for verification?
REPLY: Only upon request. If service is required it is billed at the contract hourly rate.
- Glycol Loops Testing only (Glycol if needed purchased outside of contract)
REPLY: This is not a question,

Campus Loop- Main Powerhouse: Does The University Own?

- Secondary Bulk Tanks
REPLY: No
- Tower Controller Walchem-Webmaster
REPLY: No

2.3 Scope of Work

Waste water systems- Did not see on survey.
REPLY: Waste water returns to municipal treatment plant.

What does routine services for pretreatment equipment i.e softener include?
REPLY: CCSU handles water softener operation/repairs.

All other terms, conditions and specifications in the RFP remain the same.

END OF ADDENDUM 2

