

Town of Mansfield, Connecticut Overhead Door Replacements

TO: Prospective Bid Proposers:

This Addendum forms part of the "Request for Proposal – Overhead Door Replacements" and modifies or clarifies the original "Request for Proposal – Overhead Door Replacements" for this project dated March 26, 2020. Prospective Bid Proposers shall acknowledge receipt of the addendum and submit with their bid. Failure to do so may subject the Bid Proposers to disqualification.

Questions:

The following are questions that have been received from potential bidders with the following answer provided in bold italics below:

Q1: What are the voltages for the doors? Please verify the power requirements for the correct operators.

A1: ***The voltage at the Public Works Garage door is 120 volts. The voltage at Fire Station #207 is 220 volts.***

This addendum must be signed and returned with your Bid.

Authorized Signature of Bidder

Company Name

End of Addendum No. 2